

Division of Administrative Affairs

Environmental Health and Safety Policy #MAN13

Fire Safety Manual

Version #2.0

Effective: 06/23/2023	Revised:	06/23/2023	_
-----------------------	----------	------------	---

1. PURPOSE:		
Cover page for FAU Fire Safety Manual		
2. CONTENTS:		
FAU Fire Safety Manual 62 pages.		
Approved and issued by order of:		
Wendy Ash Graves Director, Environmental Health and Safety		DATE: 06/23/2023

POLICY MAINTENANCE SECTION

Last Revision Date	06/23/2023
Last Revision By	W. Ash Graves
Next Review Due	06/23/2026
Review Frequency	3 years
Version	2.0
Time-sensitive Items	N/A

THIS POLICY RESCINDS ALL OTHER WRITTEN DIRECTIVES REGARDING THIS TOPIC.

3. RECORD OF CHANGES/STATUS CONTROL:

Version	Date	Summary of Changes	Reviewed By
2.0	06/23/23	Routine review and update	W. Ash Graves



ENVIRONMENTAL HEALTH AND SAFETY

Fire Safety Manual

Florida Atlantic University
Office of Environmental Health and Safety
June 2023

Table of Contents

1 FIRE S	SAFETY PROGRAM COMPLIANCE AND RESPONSIBILITIES	5
1.1	Introduction	5
1.2	Implementation	5
1.3	Compliance and Responsibilities	5
1.4	Responsibilities	5
1.4 1.4 1.4 1.4 1.4 1.4	1 The President of the University 2 Vice-Presidents, Deans, Chairs, and Directors 3 Employee Supervisors 4 Employees 5 Students 6 Environmental Health & Safety 7 Physical Plant 8 Housing and Residential Life 9 Facilities Management / Design Construction Services	5 6 6 6 7
	.10 Contractors PREVENTION MEASURES	
2.1	Program Strategies	
2.2	Fire Prevention Plan:	
2.3	Program Elements will include:	8
2.3 2.3	1 Prevention Measures	9 10
3.1	Office Employee Fire Safety and Training	11
3.2	Fire Safety in Residence Halls	11
3.3	Fire Safety Training for Crowd Managers	12
3.4	Fire Safety Training for Laboratory Employees	12
3.5	Fire Extinguisher Training	12
4 EMER	GENCY EVACUATION PROCEDURES	13
4.1	Emergency Evacuation	13
4.1 4.1	1 General Information	14 15
5.1	General Information	
6 PROC	EDURES FOR FIRE DRILLS	
6.1	General Information	17
6.2	Purpose of Fire Drills:	17

6.3	General Fire Drill Procedures	18
	SAFETY REQUIREMENTS FOR MEANS OF EGRESS, DOORS and CORRIDORS, AND	
7.1	Introduction	18
7.2	Basic Requirements for Means of Egress	19
7.3	Corridors/Hallways/Passageways/Ramps/Stairwells	20
7.4	Minimum Widths	20
7.5	Obstructions and Protrusions	20
7.6	Items Not Permitted in Corridors/Hallways	20
7.7	Atriums and Large Corridors	20
7.8	Fire Lanes	21
8 PLAN	NING AND MANGEMENT GUIDE FOR PUBLIC ASSEMBLY OR SPECIAL EVENTS	21
8.1	General information on Event Planning	21
	1 Fire and Life Safety	
	2 Definition of Public Assembly	
	3 Stages	
	4 Use of Tents and Canopies	
	6 Fire and Life Safety Planning and Management Information	
	AGE FIRE SAFETY	
9.1	General Storage	31
9.2	Flammable Storage	
9.3	High Stack Storage	
9.4	Housekeeping, Maintenance, and Protection of Storage Spaces	
10 ELEC	CTRICAL FIRE SAFETY	
10.1 E	Electrical Hazards Control	33
	1.1 Engineering Controls	
	1.2 Administrative Controls	
	1.3 Personal Protective Equipment	
	1.4 Training Requirements	
	1.5 Qualified Electrical Worker	
	1.5 Portable Electrical Equipment and Extension Cords	
	1.8 Working on Wet or Damp Locations	
	1.9 Working on De-Energized Equipment	
	1.10 Electrically Safe Condition	
	1.11 Working Space around Electric Equipment	
	1.12 Contractor Employees	
	SAFETY PROGRAM IN THE RESIDENCE HALLS	
11.1 F	Residence Hall Fire Safety Program Objectives	39
11.2	On-Campus Student Housing Fire Protection Equipment and Systems	39
11.3 F	ire Prevention Policies and Procedures:	40

	11.3.1 Policy on Holiday Decorations	40
	11.3.2 Policy on Electrical Equipment and Appliances	
	11.3.3 Policy on Electrical Safety	
	11.3.4 Policy on Tampering	
	11.3.6 Cooking Safety	
	11.3.7 Policy on Smoking Safety	
	11.3.8 Policy and Procedure on Fire Drills	
	11.3.9 Emergency Evacuation Procedures	
	11.3.10 Fire Alarm Reporting and Evacuation Protocols	
	11.3.11 Policy on Fire Safety Inspections	
12	2 FIRE EXTINGUISHER PROGRAM	
•		
	12.1 The Fire Triangle	
	12.2 Classes of Fires	46
	12.3 Types of Fire Extinguishers	46
	12.4 How to Use a Fire Extinguisher	47
	12.5 Rules for Fighting Fires	48
	12.6 Mounting Fire Extinguishers	49
	12.7 Tampering/Vandalism	49
	12.8 Reporting Damaged or Discharged Extinguisher	49
	12.9 Maintenance	49
	12.10 Guidelines for Inspection and Maintenance of Fire Extinguishers	49
13	12.10 Guidelines for Inspection and Maintenance of Fire Extinguishers	
13		50
13	BINSPECTION AND TESTING OF FIRE PROTECTION AND LIFE SAFETY SYSTEMS	50 51
13	3 INSPECTION AND TESTING OF FIRE PROTECTION AND LIFE SAFETY SYSTEMS	50 51 51
13	3 INSPECTION AND TESTING OF FIRE PROTECTION AND LIFE SAFETY SYSTEMS	50 51 51 51
13	13.1 Fire Protection Equipment and Systems 13.2 Servicing, Testing, and Maintenance 13.3 Service Tags	50 51 51 51
13	3 INSPECTION AND TESTING OF FIRE PROTECTION AND LIFE SAFETY SYSTEMS	50 51 51 51 51
13	13.1 Fire Protection Equipment and Systems 13.2 Servicing, Testing, and Maintenance 13.3 Service Tags 13.4 New Installation. 13.5 Upgrade of Equipment	50 51 51 51 51 52 52
13	13.1 Fire Protection Equipment and Systems 13.2 Servicing, Testing, and Maintenance 13.3 Service Tags 13.4 New Installation 13.5 Upgrade of Equipment 13.6 Inspection and Maintenance Records	50 51 51 51 51 52 52
13	3 INSPECTION AND TESTING OF FIRE PROTECTION AND LIFE SAFETY SYSTEMS 13.1 Fire Protection Equipment and Systems 13.2 Servicing, Testing, and Maintenance 13.3 Service Tags 13.4 New Installation 13.5 Upgrade of Equipment 13.6 Inspection and Maintenance Records 13.7 Notification of Systems Out of Service	50 51 51 51 52 52 52
13	INSPECTION AND TESTING OF FIRE PROTECTION AND LIFE SAFETY SYSTEMS 13.1 Fire Protection Equipment and Systems 13.2 Servicing, Testing, and Maintenance 13.3 Service Tags 13.4 New Installation 13.5 Upgrade of Equipment 13.6 Inspection and Maintenance Records 13.7 Notification of Systems Out of Service 13.8 Life Safety Systems 13.8.1 Fire Alarm Systems 13.8.2 Test of Systems	50 51 51 51 52 52 52 52 52 52 52 52
13	INSPECTION AND TESTING OF FIRE PROTECTION AND LIFE SAFETY SYSTEMS 13.1 Fire Protection Equipment and Systems 13.2 Servicing, Testing, and Maintenance 13.3 Service Tags 13.4 New Installation 13.5 Upgrade of Equipment 13.6 Inspection and Maintenance Records 13.7 Notification of Systems Out of Service 13.8 Life Safety Systems 13.8.1 Fire Alarm Systems 13.8.2 Test of Systems 13.8.3 Emergency Lighting Systems	50 51 51 51 52 52 52 52 52 52 52 52 52 52 52
13	INSPECTION AND TESTING OF FIRE PROTECTION AND LIFE SAFETY SYSTEMS 13.1 Fire Protection Equipment and Systems 13.2 Servicing, Testing, and Maintenance 13.3 Service Tags 13.4 New Installation 13.5 Upgrade of Equipment 13.6 Inspection and Maintenance Records 13.7 Notification of Systems Out of Service 13.8 Life Safety Systems 13.8.1 Fire Alarm Systems 13.8.2 Test of Systems 13.8.3 Emergency Lighting Systems 13.8.4 Generator Systems	50 51 51 51 52 52 52 52 52 52 52 52 52 52 53
13	INSPECTION AND TESTING OF FIRE PROTECTION AND LIFE SAFETY SYSTEMS 13.1 Fire Protection Equipment and Systems 13.2 Servicing, Testing, and Maintenance 13.3 Service Tags 13.4 New Installation 13.5 Upgrade of Equipment 13.6 Inspection and Maintenance Records 13.7 Notification of Systems Out of Service 13.8 Life Safety Systems 13.8.1 Fire Alarm Systems 13.8.2 Test of Systems 13.8.3 Emergency Lighting Systems 13.8.4 Generator Systems 13.8.5 Battery Systems 13.8.5 Battery Systems	50 51 51 51 52 52 52 52 52 52 53 53
13	INSPECTION AND TESTING OF FIRE PROTECTION AND LIFE SAFETY SYSTEMS 13.1 Fire Protection Equipment and Systems 13.2 Servicing, Testing, and Maintenance 13.3 Service Tags 13.4 New Installation 13.5 Upgrade of Equipment 13.6 Inspection and Maintenance Records 13.7 Notification of Systems Out of Service 13.8 Life Safety Systems 13.8.1 Fire Alarm Systems 13.8.2 Test of Systems 13.8.3 Emergency Lighting Systems 13.8.4 Generator Systems 13.8.5 Battery Systems 13.8.5 Battery Systems 13.8.6 Emergency Power Supply Systems (EPSS)	50 51 51 51 52 52 52 52 52 52 53 53 53
13	INSPECTION AND TESTING OF FIRE PROTECTION AND LIFE SAFETY SYSTEMS 13.1 Fire Protection Equipment and Systems 13.2 Servicing, Testing, and Maintenance 13.3 Service Tags 13.4 New Installation 13.5 Upgrade of Equipment 13.6 Inspection and Maintenance Records 13.7 Notification of Systems Out of Service 13.8 Life Safety Systems 13.8.1 Fire Alarm Systems 13.8.2 Test of Systems 13.8.3 Emergency Lighting Systems 13.8.4 Generator Systems 13.8.5 Battery Systems 13.8.5 Battery Systems	50 51 51 51 52 52 52 52 52 52 53 53 53 53
13	3.1 Fire Protection Equipment and Systems 13.2 Servicing, Testing, and Maintenance 13.3 Service Tags. 13.4 New Installation. 13.5 Upgrade of Equipment 13.6 Inspection and Maintenance Records 13.7 Notification of Systems Out of Service 13.8 Life Safety Systems 13.8.1 Fire Alarm Systems 13.8.2 Test of Systems 13.8.3 Emergency Lighting Systems 13.8.4 Generator Systems 13.8.5 Battery Systems 13.8.6 Emergency Power Supply Systems (EPSS) 13.8.7 Engine Driven Generator Systems 13.9 Water based Life Safety Systems.	50 51 51 51 52 52 52 52 52 53 53 53 53
13	INSPECTION AND TESTING OF FIRE PROTECTION AND LIFE SAFETY SYSTEMS 13.1 Fire Protection Equipment and Systems 13.2 Servicing, Testing, and Maintenance 13.3 Service Tags 13.4 New Installation 13.5 Upgrade of Equipment 13.6 Inspection and Maintenance Records 13.7 Notification of Systems Out of Service 13.8 Life Safety Systems 13.8.1 Fire Alarm Systems 13.8.2 Test of Systems 13.8.3 Emergency Lighting Systems 13.8.4 Generator Systems 13.8.5 Battery Systems 13.8.5 Battery Systems 13.8.6 Emergency Power Supply Systems (EPSS) 13.8.7 Engine Driven Generator Systems	50 51 51 51 52 52 52 52 52 53 53 53 53 53

13.9.2 Pi	ivate Fire Service Mains	55
	Doors and Dampers	
12 10 1	Fire Door Inspection	5.6
	Fire Door Testing	
	Fire Damper Inspections	
	ial Fire Suppression Systems	
13.11.1	Commercial Kitchen Hood Systems	56
	"Type K" Extinguishing Systems and Portable Fire Extinguishers	
	Fixed Dry Chemical Extinguishing Systems	
	Fixed Wet Chemical Extinguishing Systems	
	Fire Drill Response Form	
Appendix 2 -	FAU Event Planning Checklist	58
Appendix 3:	Request For Use of Pyrotechnics Before a Proximate Audience	61
Appendix 4 -	Request For Use of Flame Effects Before an Audience	62

1 FIRE SAFETY PROGRAM COMPLIANCE AND RESPONSIBILITIES

1.1 Introduction

The mission of the Florida Atlantic University (FAU) Environmental Health and Safety (EH&S) Fire Safety Program is to broadly increase fire safety awareness, reduce the risk and number of fires, reduce loss of life, injury and property damage through education training and inspection as well as policy and standard development. Our strategy to reduce fire deaths and injuries is to focus on prevention by identifying and rectifying unsafe behaviors. The National Fire Protection Association (NFPA) and the Occupational Safety and Health Administration (OSHA) are the primary standards used in the development of this Manual. Any area not specifically covered may be referenced in one of the above standards and will apply as necessary.

1.2 Implementation

Campus fire safety is a vitally important area of concern for FAU. The potential for loss of life or injury from a fire-related incident is one of the most serious risks a university must face. Therefore, an institution of higher education must have a comprehensive fire safety program. Fire Safety requires an on-going commitment on the part of the community, the institution, and the administration. Careful planning, implementation, and maintenance are all essential ingredients of a successful fire safety program.

1.3 Compliance and Responsibilities

FAU faculty, staff, students, service providers, contractors, and visitors must comply with this program due to the danger of injury or death from fire-related emergencies. Any emergency situation must be reported to FAU Police while any potentially hazardous situation must be reported to FAU EH&S. Failure to do so could result in the possible loss of life and damage to property. Persons who knowingly and/or willingly violate the provisions of this program may be subject to disciplinary action. Tampering with or disabling a Fire Alarm or Sprinkler System is a crime and will be referred to the FAU Police. The responsibilities for campus fire prevention rest on all levels of FAU and are outlined as follows:

1.4 Responsibilities

1.4.1 The President of the University

As the chief executive, the President has ultimate responsibility for establishing and maintaining environmental health and safety programs for FAU and provides continuing support for the Fire Safety Program. These responsibilities have been delegated to the Director, Environmental Health and Safety through University Policy 4.1.2 Environmental Health and Safety.

1.4.2 Vice-Presidents, Deans, Chairs, and Directors

These administrators are responsible for enforcing fire safety programs in areas under their control, and aiding the FAU EH&S Department in conducting safety inspections, correcting

violations, and implementing fire prevention and evacuation policies as well as encourage and require employees to participate in fire safety trainings and awareness programs.

1.4.3 Employee Supervisors

Employee Supervisors must brief their employees on the specific hazards of their work area, on fire reporting and evacuation plans, and fire extinguisher locations. Supervisors are responsible for identifying employee training needs, assigning EH&S fire safety training, and ensuring training completion. Supervisors will strive to be exemplary in fire prevention and require employees to participate in fire drills so that they become familiar with their area escape plan.

1.4.4 Employees

FAU employees are to receive an overview of the safety programs provided by EH&S and should become familiar with the services. All FAU employees are required to complete fire prevention training in addition to other fire-related training that may be specific to their role and responsibilities as well as what to do in a fire emergency. Employees shall comply with fire safety policies and guidelines, report any observed unsafe condition, and complete assigned training as required.

1.4.5 Students

Students should familiarize themselves with the fire safety guidelines of FAU. Students residing in FAU Residence Halls shall also be familiar with Housing and Residential Life rules. Students should report any vandalism of fire safety equipment or observed fire hazards to EH&S or Housing and Residential Life. Students are required to evacuate the building during a fire alarm or fire emergency and proceed to pre-determined assembly areas of their buildings and wait there until told to re-enter the building.

1.4.6 Environmental Health & Safety

- Oversight of the Fire Safety Program at FAU
- Provides a fire-safe environment for employees, faculty, students and visitors.
- Coordinates and reports fire code compliance inspections.
- Inspects, tests, and maintains fire detection and suppression systems through a certified subcontractor.
- Inspects and tests emergency exit signs and lighting and other life safety systems.
- Responds to fire incidents and assists with the follow-up.
- Acts as liaison to the State Fire Marshal and coordinates corrective actions with responsible parties.
- Acts as liaison to other local and state regulatory agencies related to fire and life safety.
- Assists and advises University departments on matters relate to fire and life safety issues.
- Participates in the design of fire detection and alarm system standards.
- Monitors fire detection and fire suppression systems.

- Develops and publicizes university fire program and policy.
- Conducts emergency evacuation exercises.
- Provides fire safety education and training.
- Review plans.
- Participates in the design, construction, and renovation of buildings through the process of plans review and construction inspections.

1.4.7 Facilities

- Corrects fire code deficiencies in a timely manner.
- Repairs and maintains identified life safety devices (ie. Exit signs, emergency lights, electrical life safety circuits).
- Notifies EH&S of any interruptions in a building's water supply which might affect fire sprinkler performance.
- Notifies EH&S of any construction activities which might affect fire alarm or sprinkler operations.
- Obtains State Fire Marshal Permits as part of all construction/renovation activities under their corresponding purview.
- Assists in the design of fire suppression, detection and alarm systems.
- Ensures compliance of FAU Hot Work Permit Policy implementation for all activities under their purview.

1.4.8 Housing and Residential Life

- Provides fire safety education for student residents and housing staff.
- Conducts monthly in-house code compliance inspections for residence halls and apartments.
- Participates in the FAU Fire Safety awareness programs.
- Inspects, tests, and maintains all fire safety equipment.
- Assists and coordinates emergency evacuation exercises for housing units.
- Corrects fire code violations in a timely manner.
- Ensures compliance of FAU Hot Work Permit Policy implementation for all activities under their purview

1.4.9 Facilities Management / Design Construction Services

- Develops and maintains a university design manual.
- Develops fire suppression and detection system specifications.
- Participates on University Fire Safety awareness strategies.
- Notifies EH&S of any construction/renovations activities which might affect fire alarm or sprinkler operations.
- Obtains State Fire Marshal Permits as part of all construction/renovation activities under their corresponding purview.
- Ensures Life Safety Code Compliance for new and renovated buildings.

- Ensures compliance of FAU Hot Work Permit Policy implementation for all activities under their purview
- Executes fire code corrections that require Capital Outlay funding.

1.4.10 Contractors

- Comply with local, state, and federal safety standards.
- Complies with FAU Hot Work Permit Policy.
- If the contractor has an established program that meets or exceeds FAU policy, it may be used on the job site. If the contractor does not have such program, FAU policies may be mandated. The more restrictive requirements will apply.

2 FIRE PREVENTION MEASURES

2.1 Program Strategies

Fires require fuel, an adequate oxygen supply, and an ignition source to start. Fire prevention is accomplished by maintaining control over one of the three required elements that, when brought together, cause fires. The strategies we follow will include the following:

- 1. Implement a program that targets preparation, prevention and emergency preparedness and evacuation.
- 2. Proper handling of combustible and flammable materials.
- 3. Proper handling and control of all ignition sources.
- 4. Implement safe housekeeping practice that reduces the risk of fire danger.
- 5. Install a reliable fire protection system and maintenance procedures.
- 6. Disseminate fire safety information through education, training and other means of an awareness program.

2.2 Fire Prevention Plan:

The purpose of the plan is to eliminate the causes of fire and prevent loss of life and property by fire. The plan provides faculty, staff and students with information and guidelines which will assist in recognizing, reporting and controlling as well as eliminating the causes of fires and fire hazards.

2.3 Program Elements will include:

- 1. Identifying potential fire hazards with an emphasis on the proper handling of combustible and flammable materials.
- Control and proper usage of ignition sources with an emphasis on electricity which is the major ignition source in all occupancies. Ignition sources also exist in chemical and mechanical forms. Smoking, open flames like candles and hot burners as well heat producing elements.

The major causes of fire at the workplace include poor housekeeping, improper storage and use of flammable materials, overloaded electrical outlets and extension cords, misuse of heat-producing appliances including space heaters, unsupervised cooking, and the use and improper

disposal of smoking materials on campus grounds. Implementing fire prevention measures is the key in an attempt to ensure one's personal safety.

2.3.1 Prevention Measures

- Familiarize yourself with your building's emergency exits, the routes to the emergency exits, and where fire extinguishers are mounted.
- Recognize all possible risks associated with an activity or process and eliminate it by controlling sources of ignition and properly managing combustible and flammables.
- Regularly observe emergency evacuation routes, fire extinguishers, and emergency and exit lights. Immediately report any missing equipment or any other problems discovered to EH&S.
- Encourage occupants to actively participate in fire drills that are conducted regularly.
- Regularly observe the lobby, corridors, stairwells, and keep them clear of obstructions.
- Regularly observe all exits to keep them clear of obstructions AT ALL TIMES.
- Report any tampering with the fire alarm, smoke detection and suppression systems to EH&S.
- Regularly observe fire doors to make certain they are closed at all times; report inoperable doors to Physical Plant or the respective maintenance offices.
- Inspect offices in search of:
 - Overloaded circuits
 - o Frayed or damaged electrical cords
 - Improperly used extension cords
 - o Improperly used appliances
- Forbid the use of candles or any other open flame devices for any purpose in FAU buildings.
- Enforce the "No Smoking Policy" at all FAU properties.
- Enforce all Florida Atlantic University safety regulations. If there are questions, contact EH&S.

2.3.2 Housekeeping

- Fire doors must be kept closed at all times unless they are held open by a SFM approved device that will automatically close in the event of a fire alarm.
- Exits, stairways, corridors, and egress pathways leading to and from exits must be kept free of obstructions at all times. Furnishings, decorations, combustible objects, or flammables must not block exits, access to exits, or any means of egress.
- Dispose of all trash as soon as possible in trashcans or dumpsters. Waste materials must never be piled in corridors or stairwells while awaiting removal.
- Flammable materials should be present in the work area only in the quantities required for the day's job. These materials must be placed in an approved storage area at the end of each day.
- Materials must not obstruct sprinkler heads or be piled around fire extinguishers, fire alarm pull stations, or sprinkler and stand pipe control values. To obtain proper distribution of water from sprinklers, a minimum of 18 inches of clear space is required below sprinkler deflectors.

2.3.3 Electrical Wiring and Appliances

- Supervisors should periodically inspect all electrical equipment and cords to ensure proper use and safe conditions. Improper use of electrical devices to obtain more outlet capacity can result in overloaded circuits and fire.
- The use of extension cords should be minimal and shall only be used when a flexible, temporary connection is necessary. The cord and the outlet should be checked periodically to ensure overheating is not occurring. Extension cords cannot be used for fixed or permanent wiring, and should never be tacked, stapled, tied, hidden under rugs or draped over pipes or other supports, fastened to or through woodwork, ceilings or walls. When there is a permanent need of an electrical outlet, installation shall only be completed through the proper work order or minor project request.
- Surge protector/power tap use is permitted. They must plug directly to a wall outlet and the equipment must be directly plugged into the surge protector. All surge protectors are to be UL 1363 or 1363a listed and bear the UL symbol. Only one appliance can be plugged into a surge protector at a time. The following are some of the items that are not permitted:
 - Any outlet multiplier, a device that increases the number of available plugs but provides splices (the little box that makes one plug into three)
 - Outlet boxes (usually silver box with 4 plugs on top and a long black cord)
 - Home use extension cords (usually brown, green or white light weight cords)
 - Heavy duty extension cords (when not being used temporarily)
- Be sure all electrical equipment is properly grounded. If any evidence is found of modified, frayed, cracked or damaged wiring or electrical outlets, the equipment affected should be taken out of service until repairs are made.
- Space heaters, coffee makers, microwave ovens, toasters and all other appliances with exposed heating elements should never be left unattended while in operation. Space heaters shall not be placed under desks or in other enclosed areas. These appliances should be unplugged after each use and stored only after they are cool enough to touch. They should be operated away from combustible materials such as files, curtains, trash containers, etc., AND MUST BE KEPT AT LEAST 3 FEET AWAY FROM ALL COMBUSTIBLE AND FLAMMABLE MATERIALS.

3 GUIDELINES FOR FIRE SAFETY EDUCATION AND TRAINING

FAU EH&S serves the community by addressing all aspects of the natural and built environment that can affect the health and safety of students, staff, faculty and visitors. It does so through an educational process of training and other service-oriented programs.

At the core of the program is the education and knowledge which we believe is the key to save lives, test and train occupants in fire safety awareness, and bring a higher level of understanding of what is involved in order to prevent and more importantly SURVIVE A FIRE. In essence, the goal is to provide knowledge so as to understand the origin of fires, sources of fires, how to prevent fires from occurring and finally what to do if one is faced with fire.

The fire safety training is organized in such a way as to meet the specific needs of groups of people based on the kind of fire hazards to which they are exposed.

The theme of each of the training requirements discussed below is to help participants learn:

1. FIRE PREVENTION (Stopping Fire From Occurring)

Training Topics:

- What is fire?
- What are the possible causes of fire?
- What needs to be done to prevent the possible causes of fire?
- · Actions to take to mitigate fires, inspection, hazard reporting,

2. EMERGENCY PREPAREDNESS AND EVACUATION (What Action To Take In Case Fire Occurs In A Building)

Training Topics:

- How to prepare for a fire emergency.
- Participation in fire drills.
- Knowing evacuation procedures
- Knowledge and maintenance of fire protections systems
- Know how to use proper type of fire extinguisher

3.1 Office Employee Fire Safety and Training

FAU workplace fire safety guidelines are primarily derived from the Florida Fire Prevention Code which contains the NFPA Life Safety Code (NFPA 101) 2018 Florida Edition. These regulations apply to buildings and work areas and provide basic requirements for the protection of property and life and the prevention of fires and explosions. OSHA requires employers to have a Fire Prevention Plan and to inform their employees of fire hazards to which they are exposed upon initial assignment of their jobs.

The Fire Safety and Prevention Training, administered through the EH&S Training Website and the Precipo online training platform, has been selected to inform FAU employees of general fire hazards to which they may be exposed to as part of job duties. Employee Managers are to assign this training to new employees as well as review the emergency evacuation procedures for their workplace building, understand the threat and power of fire, and learn what to do in case of fire. This includes being familiar with the basics of fire protection systems, fire prevention and safety, the basics of fire extinguishers, and how to use them.

3.2 Fire Safety in Residence Halls

The FAU Residential Hall Fire Safety Program includes the completion of Fire Safety and Prevention Training as well as the Portable Fire Extinguisher uses. Topics included in these training modules include identifying the possible causes of fire, fire prevention techniques, emergency planning, familiarizing with evacuation plans, the completion of fire drills and basic concepts on fire protection systems. Additional hands-on fire extinguisher use training, which is offered by EH&S on a monthly basis, is a vital part of this training module. FAU Housing Staff, which include Resident Advisors (RA's), housing administrators, and maintenance staff are

directed to complete these training modules as well as the supplementary hands-on fire extinguisher training.

3.3 Fire Safety Training for Crowd Managers

The Florida Fire Prevention Code requires Assembly occupancies be provided with a trained crowd manager or crowd manger supervisor. Where occupancy exceeds 250, additional trained crowd managers/supervisors are required at a ratio of one per 250 occupants. This ratio may be reduced by the Authority Having Jurisdiction (AHJ) in areas serviced by an automatic sprinkler system and if the nature of the events warrants. Crowd Management training provides guidance and education to departments that host large size indoor and outdoor activities or events, or departments that have Class A & B occupancy facilities such as theatres auditoriums, gymnasiums etc. The training covers requirements that need to be met during an event, procedures that need to be in place to ensure safety of the crowd and the organizers. Participants will learn about basic fire prevention concepts, how fire protection systems work, what to do in case of a fire emergency including how to work with emergency responders, occupancy classifications and occupant load limits as well as how to deal with crowd. Event managers, people in charge of assembly areas/auditoriums are to complete this training.

3.4 Fire Safety Training for Laboratory Employees

Fires and explosion are the most serious physical hazards faced in typical laboratory, research and experiment settings. Laboratories typically contain a high concentration of fuel loads, in the form of flammable and combustible liquids, pressurized gas cylinders, as well as different ignition sources that may be electrical, chemical or mechanical. This combination of fuel loads, explosive hazards, and ignition sources result in laboratories being high hazard areas to work in.

Laboratory employee training includes the completion of Fire Safety and Prevention Training as well as Portable Fire Extinguisher Training. This training outlines the handling of flammable and combustible liquids including hazardous waste materials (fuel loads) and the containment of ignition sources that may electrical, chemical, or mechanical in nature. This training also addresses the proper procedures to follow for preparing for a fire emergency and what to do should a fire emergency occur. The completion of Portable Fire Extinguisher Training and the hands-on fire extinguisher supplemental training; both presenting the different types of fire extinguisher as well as their practical use is also an important part of the training regimen. Lab supervisors, technicians, student and faculty members who teach and work in labs participate in this training.

3.5 Fire Extinguisher Training

FAU EH&S offers Portable Fire Extinguisher Training and the hands-on fire extinguisher supplemental training as an education program to familiarize employees not expected to conduct incipient stage firefighting with the general principles of fire extinguisher use and the hazards involved with incipient stage firefighting. This training program provides extensive information on the classification of fires, portable fire extinguisher classification, operation of portable fire extinguisher, and the hazards involved in fighting an incipient stage fire. The hands-on fire

extinguisher supplemental training provides attendees with the opportunity to actually use fire extinguisher to put out a small fire.

4 EMERGENCY EVACUATION PROCEDURES

The purpose of establishing Emergency Evacuation Procedures is to set minimum requirements that will provide a reasonable degree of life safety from fire and similar emergencies in FAU buildings and structures. The Emergency Evacuation Procedures will be utilized to evacuate all occupants during a fire emergency. Failure to leave the building when a fire evacuation alarm is sounding is a violation of state law.

4.1 Emergency Evacuation

4.1.1 General Information

What conditions may warrant evacuation of a building?

- Fire,
- Bomb Threat,
- Hazardous Material Spill,
- Hostile Intruder,
- Utility Failure, etc.

What should I know about the building evacuation plan?

- KNOW the evacuation plan of the building and where to find it. (Look for postings and consult your Supervisor)
- KNOW the location of all exits for the building.
- KNOW the locations of emergency equipment (i.e., fire extinguishers, pull stations, emergency telephones, designated areas of refuge, AEDs, etc.).
- KNOW the location of the assembly area outside the building (consult your Supervisor).
- ASSIST and participate in fire drills.

What should I do when I hear a fire alarm, or get an order to evacuate without an activated alarm?

- TURN OFF ALL HAZARDOUS EXPERIMENTS or procedures before evacuating.
 Take or secure valuables, wallets, purses, keys, etc. as quickly as possible and only if it is safe to do so.
- CLOSE all doors behind you as you exit.
- CHECK all doors for heat before you open or go through them to avoid walking into a fire.
- EVACUATE the building using the nearest exit or stairway. **DO NOT USE ELEVATORS.**
- CALL 911 from a safe area and provide name, location, and nature of emergency.
- PROCEED to pre-determined assembly area of building and remain there until you
 are told to re-enter by the emergency personnel in charge.

- DO NOT IMPEDE access of emergency personnel to the area.
- INFORM FAU Police or Emergency Personnel of the event, conditions and location of individuals who require assistance and have not been evacuated.

What should I do to initiate a fire alarm to evacuate a building?

Activate Fire Alarm Pull Station Located at Various Places Along Exit Routes.

4.1.2 Individuals Requiring Assistance

What should I know as an individual requiring assistance?

- LEARN the locations of exit corridors, exit stairways, designated areas of refuge (AORs), and if your AOR has a communication feature to notify first responders of your presence.
- PLAN an escape route.
- TELL a co-worker or supervisor how you will need assistance in case of emergency.

What should I do, as an individual requiring assistance, during a building evacuation?

- WAIT near the closest stairway, entrance or designated AOR and wait for assistance from others.
- Utilize the AOR's notification system (if one is present) you are located at or your phone (if
 one is not present) to directly contact FAU Police Department (FAU POLICE), 911, or a 24hr monitoring service to request assistance.
- DO NOT USE ELEVATORS

What should I know/or do to help individuals requiring assistance?

- KNOW the needs and capabilities of people requiring assistance who are routinely in your work area.
- ASK how you can help anyone requiring assistance before giving it.

GENERAL GUIDELINES:

- INDIVIDUALS WHO ARE BLIND OR VISUALLY IMPAIRED:
 - o OFFER assistance verbally and guide them to the nearest exit.
 - DO NOT GRAB THEIR HANDS AND PULL THEM ALONG. Instead, offer your elbow to them. It is easier to hold on to a sighted person's elbow during an evacuation. If possible, someone should follow behind to protect the individual from being pushed down in the event of crowding.
- INDIVIDUALS WHO ARE DEAF OR HARD OF HEARING:
 - Get their attention and convey information by using hand gestures or writing what is happening and where to go.
 - Guide them to the nearest exit.
- INDIVIDUALS WHO MAY NOT BE ABLE TO RESPOND TO AN EMERGENCY SHOULD BE CALMLY ADVISED AND GUIDED TO THE EXIT
- INDIVIDUALS WHO ARE IMMOBILIZED OR HAVE A MOBILITY DISABILITY:
 - These include individuals wearing casts and/or using canes or crutches, or those who are wheelchair bound, and those sustaining injuries during the emergency that render them immobile.

- They should be given assistance based solely upon their ability to maneuver through doorways and up/down stairs to REDUCE THE RISK OF PERSONAL INJURY. They should not be evacuated by untrained personnel unless the situation is life-threatening (Fire Rescue/Police personnel are trained personnel).
- If located on an upper floor, individuals may be assisted to a stairway entrance or designated AOR to await evacuation or further instructions from Fire/Rescue or Police. If the individual is capable of walking with assistance, a "buddy" should assist and accompany the individual when descending the stairs.
- Utilize the AOR's notification system (if one is present) you are located at or your phone (if one is not present) to directly contact FAU POLICE, 911, or a 24hr monitoring service to request assistance.

What should I do to assist individuals who cannot maneuver up/down stairs?

- GUIDE THE INDIVIDUAL quickly to a designated AOR or a location of reasonable safety such as to a stairway entrance and out of way from the stream of traffic.
- Utilize the AOR's notification system (if one is present) you are located at or your phone (if
 one is not present) to directly contact FAU POLICE, 911, or a 24-hr monitoring service to
 request assistance.
- ACCOMPANY ANY ACTION by a verbal explanation so that the person being assisted understands what is happening and why these actions are being taken.
- CONTACT FAU POLICE immediately if a telephone is available, and provide the following:
 - The individual's name and location within the building
 - The phone number from which the call is being made.
- If left alone, the individual may wish to remain on the phone with FAU POLICE.
- IF AVAILABLE, A COMPANION, OR OTHER RESPONSIBLE PERSON may remain with and assist the individual.
- INFORM the FAU POLICE or emergency personnel of the exact location of the individual(s) with the disability(ies).

Trained, equipped, emergency personnel will facilitate the evacuation of individuals with disabilities.

4.1.3 Student Residents - Individuals Requiring Assistance in On Campus FAU Dormitories

In the event of a fire alarm, electrical outage, or other occurrence which impedes the operation of the elevators in a given building, it is essential that Housing, Police, Fire, Medical, or other personnel be prepared and able to assist students who are unable to egress the building. Should you become injured and as such be temporarily unable to ascend or descend stairs easily, please contact the Area Office staff so they may update their records.

 Atlantic Park Towers (APT/Bldg. 111) and Indian River Towers (IRT/Bldg. 70): The student should proceed to the stairwell closest to their location when the emergency arises. Should this area be inaccessible, the student should proceed to the opposite stairwell on the floor. The student should press the intercom in the stairwell to alert the Area Office personnel of their position. A Residential Education Staff Member will report to that location

- to wait for emergency personnel. Another Residential Education staff member will remain at the entrance to the building to escort emergency personnel to the student's location.
- Heritage Park Towers (HPT/Bldg. 89) and Glades Park Towers (GPT/Bldg. 92): The student should proceed to the center stairwell of the building when the emergency arises. Should this area be inaccessible, the student should proceed to the corner stairwell of the building. A Residential Education staff member will climb the center stairwell until they reach the student. Should the center stairwell be vacant, the Residential Education staff member will walk down the corner stair- well until they reach the student. The Residential Education staff member will be in contact with the Area Office staff via two-way radio to keep them apprised of the situation. The Area Office staff will escort emergency personnel to the student's location.
- University Village Apartments: The student will proceed to the closest building with elevator access (Building 56 or 61). A Residential Education staff member will report to both locations to ensure that all students who need assistance have been evacuated. The Residential Education staff member will be in contact with the Area Office staff via phone to keep them apprised of the situation. The Area Office staff will escort emergency personnel to the student's location.
- Innovation Village Apartments (IV/Bldgs. 98 & 99): The student will proceed to the elevator. A Residential Education staff member will report to the location to ensure that all students who need assistance have been evacuated. The Residential Education staff member will be in contact with the Area Office staff via phone to keep them apprised of the situation. The Area Office staff will escort emergency personnel to the student's location.

5 FIRES AND FIRE SAFETY

5.1 General Information

What should I do if I discover a fire?

- ACTIVATE THE FIRE ALARM SYSTEM by pulling one of the nearest pull stations that are located along the exit routes, **if the alarm is not already sounding**.
- FOLLOW YOUR EVACUATION ROUTE and evacuate the building through the nearest exit if the alarm is sounding. DO NOT USE ELEVATORS.
- PROCEED to the pre-determined outdoor assembly area for the building.
- CALL 911 or FAU POLICE to report the fire, after you evacuate the building.
- REMAIN OUTSIDE at the assembly area until you are been told to re-enter the building by the emergency personnel in charge.

What do I need to know about portable fire extinguishers?

- Portable fire extinguishers are installed throughout FAU buildings.
- Familiarize yourself with the locations of the fire extinguishers and receive hands-on training.
- Fire extinguishers can only be used for small fires that are contained and not spreading beyond its starting point.
- Multi-purpose ABC fire extinguishers are used to fight Class "A", "B" and "C" fires:
 - Class "A": Fires caused by ordinary combustibles, such as wood, paper or textiles.

- Class "B": Fires caused by flammable and combustible liquids, such as cooking oil, gasoline, and other solvents.
- o Class "C": Fires caused by electrically-energized equipment or appliances, etc.

When should I use a portable fire extinguisher?

Attempt to use fire extinguishers ONLY if the following apply:

- You are trained on how to use the fire extinguisher.
- The proper extinguisher is readily available.
- The fire is small, contained, and not spreading beyond its starting point.
- The exit is cleared and there is no imminent peril.
- The building is being evacuated.
- The fire department is being called.

How do I use a fire extinguisher?

To operate your extinguisher, remember the word **PASS**.

- P Pull the pin
- A Aim low at the base of the fire
- S Squeeze the lever
- S Sweep across the fire
 - Contact EH&S immediately to replace any used fire extinguisher at (561)297-3129.

How do I prevent fires from occurring?

Speak to Supervisor to be assigned Fire Safety and Prevention Training by FAU EH&S. Check for the following fire hazards at all times and report to EH&S or call FAU POLICE:

- The occurrence of smoking.
- Exits not clearly marked or means of egress blocked by storage.
- Trash and other combustibles have not been disposed of regularly
- Improper storage of flammable and combustible liquids.
- Electrical hazards, such as overloaded outlets, unapproved types of extension cords, exposed wires and power cords that are in poor condition.
- Use of open flames / candles.

6 PROCEDURES FOR FIRE DRILLS

6.1 General Information

FAU EH&S or its designees conduct fire drills in University buildings as required by state law. The primary concern in the event of a fire is to get everyone out of the building as quickly as possible. To do this, occupants must be prepared in advance for a quick and orderly evacuation. A trained group will act more calmly under emergency situations, thereby dispelling panic, which has caused more casualties than fire itself. Slow evacuation and panic account for the large majority of all fatalities in fires.

6.2 Purpose of Fire Drills:

- To allow occupants to familiarize themselves with evacuation procedures, the location of fire exits, and the visual and audible signals of the fire alarm.
- To allow EH&S to monitor the timeliness and effectiveness of evacuations.
- To detect technical problems with the fire alarm equipment.
- To gauge whether or not persons evacuate the building as legally required.
- To check if fire protection equipment, such as fire doors are functioning and being used properly.
- To gauge how long it takes to evacuate each building, and which exits are generally used.

6.3 General Fire Drill Procedures

- Fire drills are arranged and supervised by the FAU Fire Safety Officer, or designee, with the cooperation of the entity responsible for the building and/or the FAU POLICE.
- The date and time will be scheduled when most occupants are in the building.
- The FAU Fire Safety Officer, or designee, will inform FAU POLICE of the exact times the alarm will be pulled for the drill.
- The FAU Fire Safety Officer, or designee, will activate the fire alarm.

WHEN THE EVACUATION ALARM SOUNDS, "EVERYONE MUST LEAVE THE BUILDING"

- After evacuation, occupants shall proceed to a pre-determined location and wait for the instruction of emergency personnel to re-enter.
- The FAU Fire Safety Officer, or designee, shall silence and reset the panel when everyone has evacuated the building.
- Fire drills will be monitored for effectiveness and documented using the <u>FAU Fire Drill</u> Response Form which is included as **Appendix 1**.
- If the fire drill is completed by a designee, the designee shall complete <u>FAU Fire Drill</u> Response Form, and send it to The FAU Fire Safety Officer.
- The department or entity responsible for the building shall receive a completed copy of the <u>FAU Fire Drill Response</u> <u>Form</u> from The FAU Fire Safety Officer after the completion of every drill.
- Fire drills will be held at least:
 - o Once per semester in on Campus residential dormitories.
 - Monthly at Bezos Academy Child Care Center (Bldg. 45 & 45a)
 - Monthly at The Memory and Wellness Center (Bldg. 79 & 79A)
 - o 10 times a year at Henderson University School (Bldgs. 26 through 26J)
 - Annually in all other buildings

7 FIRE SAFETY REQUIREMENTS FOR MEANS OF EGRESS, DOORS and CORRIDORS, AND FIRE LANES

7.1 Introduction

A means of egress is an exit path that occupants may use to safely exit a building. It is designed to provide safe and easy travel during a fire, or other emergency, so that the risk of injury or death

is minimized. Most facilities have more than one means of egress, though the exact number of exits depends on the building's function, design, and occupancy load. Once in place, exit paths must be carefully maintained to ensure they are not blocked or compromised during normal building operation.

A means of egress is a continuous and unobstructed way of exit travel from any point in a building or structure to a public way, which allows occupants to promptly exit a building or structure in the event of an emergency.

A means of egress consists of three parts: exit access, exit, and the exit discharge. Exit access is the path from any location within a building to an exit. An exit is typically a door leading to the outside or, in a multi-story building an enclosed exit stairway. Exit discharge is the pass from the exit to the public way. A public way is a space that is permanently dedicated to public use, most often a street or alley.

Looking at the typical causes of fire deaths, blocked exits are probably the most preventable and most likely to result in criminal negligence charges. FAU has a responsibility to provide a safe environment to anyone working, learning or attending events within a building. It is therefore essential that there is access for quick evacuation during an emergency and the guidelines below are strictly observed.

7.2 Basic Requirements for Means of Egress

- For any room or space with only one exit a maximum occupant load should not exceed 50 people.
- For any room or space with only two exits, the maximum occupant load should not exceed 500 people.
- For any room or space with only three exits, the maximum occupant load should be 1000 people.
- For rooms more than 50 occupants, doors must swing in the direction of egress.
- For rooms more than 100 occupants, doors should be equipped with panic hardware.
- Exit doors should lead to a corridor, an exit stair enclosure, or directly to the exterior of a building. Exits should not pass through adjacent rooms or through hazardous areas such as kitchens, storage rooms, loading docks etc.
- Doors act as a barrier for fire and smoke and to serve as components in a means of egress.
- The self-closing devices shall not be disconnected or rendered inoperable.
- Fire and smoke rated doors shall not be blocked open. Obstructions that will prohibit fire and smoke rated doors from closing and latching without human intervention are not permitted.
- Door chocks or foot stops may not be installed on any fire rated door.
- Exit doors must not be equipped with locking hardware that would allow an occupant to be locked inside the room or space.
- Exit doors should also not be equipped with secondary locking devices, such as a dead bolt
 or slide bolt etc. It should be possible to open any designated exit door using a single
 motion, without the use of key, tool or special knowledge.
- The means of egress including the exit discharge shall be illuminated at all times the building is occupied.
- Gates used as a component in a means of egress shall conform to applicable requirements to doors.

- Turnstiles or similar devices that restrict travel to one direction shall not be placed so as to obstruct travel to one direction and shall not be placed to obstruct any required means of egress.
- Where required, exit and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel.

7.3 Corridors/Hallways/Passageways/Ramps/Stairwells

Corridors, hallways, passageways, ramps and stairwells etc. are designed and constructed to allow people to exit the building by the safest and quickest method possible devoid of any obstructions or protrusions.

7.4 Minimum Widths

- Minimum widths (which increase according to the number of people) range from, 18 " between desks, to 44" for corridors depending on the occupancy type.
- Furniture, artwork, wall hangings, statues, etc., which protrude from walls may not obstruct the minimum width, nor present a tripping, injury or other safety hazard.
- Minimum aisle widths must be maintained at all times.

7.5 Obstructions and Protrusions

- No corridor, aisle way or component of a means of egress may be obstructed.
- Non-combustible furniture in lobbies must not obstruct the minimum width of egress and must be arranged so there is a direct path through the lobby to the EXIT.
- Wires, cables or extension cords may not be laid across corridors, aisles or pathways.
- Minimum ceiling height in exit passageways is 7'6". Lights, decorations, signs or any other items hung from the ceiling may not be lower than 6'8".
- Wires or cables hung from the ceiling must not present a safety hazard such as snagging equipment being transported through the corridor.

7.6 Items Not Permitted in Corridors/Hallways

- Any Combustible or Flammable storage cabinets of any size.
- Compressed gas bottles of any size.
- Carts, cabinets, shelves or other items on which combustibles or flammables are likely to be stored.
- Chemicals, munitions, pyrotechnics or any other hazardous material.
- Any item that will impede the normal or emergency flow of traffic or will obstruct any emergency device.
- Portable heaters, coffee pots, food warmers or other devices that may present a hazard.
- Unprotected high voltage, electrical or gas-powered equipment of any sort, material and overstuffed furniture boxes, etc.

7.7 Atriums and Large Corridors

The open spaces at the base of atriums and large corridors must be left clear at all times. If there is a need to use these open spaces temporarily for any kind of function, it must be done in a way that is not obstructing egress. EH&S must be consulted in advance for proper safety precautions.

7.8 Fire Lanes

In the event a fire should occur, it is critical that emergency responders be able to access the building, or location of the emergency. Fire lanes and emergency access routes have been provided for this purpose.

- Fire lanes, normally marked with red or yellow paint on the curb, may not be blocked at any time. This includes temporary parking for the purpose of loading or unloaded. Emergency vehicles have the right-of-way. All vehicles will, when an emergency vehicle approaches from any direction, immediately pull over to the right side of the road to give passage to the emergency vehicle.
- Fire hydrants, fire department connections, or other emergency equipment may not be obstructed at any time. Parking is prohibited within 15 feet of a fire hydrant, or fire department connections.

8 PLANNING AND MANGEMENT GUIDE FOR PUBLIC ASSEMBLY OR SPECIAL EVENTS

8.1 General information on Event Planning

8.1.1 Fire and Life Safety

Fire safety is a primary consideration for all events, event sites, event workplace, and event operation. It encompasses the prevention of fire as well as the safety of people and protection property should a fire occur as well as the ability to evacuate people and provide response access to fire fighters and their equipment. See <u>Appendix 2 – FAU Event Planning Checklist</u> for a detailed list of considerations.

All persons planning public assembly events are encouraged to contact EH&S for information and assistance. Consultation is available by telephone, email, meetings and at the desired event site. All events not utilizing a space with a pre-determined layout approved by EH&S and the Office of Space Utilization will require a layout be generated which depicts the location and spacing of all equipment, tents, activities, etc. associated with the event. This event layout must be evaluated by EHS, and potentially other departments (FAU POLICE, Office of Space and Utilization, Parking and Transportation, etc.)to ensure that the appropriate fire safety precautions and emergency plans are in place based on the type and scope of event taking place. When necessary a life safety evaluation will be conducted to ensure adequacy of life safety features, fire prevention and fire suppression capabilities, means of egress and the ability of occupants to exit safely and quickly if a fire or other emergency should occur.

In order to comply with the requirements of the State Fire Code, it is necessary for EHS to make or obtain certain approvals and inspections as noted in these guidelines. These approvals and inspections will require approval by the AHJ which may be the State Fire Marshal, local responding Fire Department, and/or EH&S. Required approvals and inspections should be requested as far in advance as possible. Local fire department officers have to be present for certain events such as indoor pyrotechnics, outdoor fireworks and large-scale events.

8.1.2 Definition of Public Assembly

Public assembly events involve various risk factors associated with having numbers of people in one location. The primary risk factors are high occupant density, occupants that are not familiar with the buildings, and in some case darkness. These risks can be managed through proper event planning and management.

The Florida Fire Prevention Code defines public assembly occupancy as follows:

An occupancy (1) used for gathering together 50 or more persons for deliberation, worship, entertainment, eating, drinking, awaiting transportation, or similar uses; or (2) used as a special amusement building, regardless of occupant load. (NFPA 101 FL Life Safety Code 3.3.196.2).

Examples of assembly occupancies found on the FAU campuses include large meeting rooms and classrooms, auditoriums with fixed seats or loose chair seating, multipurpose rooms, concert halls, theaters, sport arenas, field houses, restaurants and libraries. Tents are considered buildings under the Florida Fire Prevention Code and must meet **most of the requirements of buildings.** Please see section 8.1.4 below.

8.1.3 Stages

Enclosed open areas such as an outdoor stage must meet the same requirements as buildings. Fenced open areas must have at least two exits. All stages must receive a FAU Building Permit through EH&S and be inspected before use.

8.1.4 Use of Tents and Canopies

This section shall be followed when tents and canopies are used on campus either for recreational or gathering purposes. A canopy is defined by fire code as any temporary membrane structure with 75% or more of its sides open without sidewalls whereas tents have more than 25% sidewall coverage. All tents or canopies larger than 10ft by 10ft are required to obtain a FAU Tent Permit through EH&S and be inspected before use as well as approval through University Space Utilization and Analysis.

Inspections:

All tents and canopies with an occupancy load of more than 50, or any tent larger than 10ft by 10 ft feet, or any canopy in excess of 800 square feet, must be inspected by EH&S before use and must meet the following requirements.

Tent/canopy erection and set-up considerations:

 Office of Space and Utilization must be notified of all tent and canopy activities on campus so that appropriate lawn mowing, pest control and utility marking can be accomplished.

- 2. If the event includes the staging of multiple tents/canopies in the same vicinity that will include a cooking tent/canopy to support the event, a site plan must be presented to EH&S prior to erection of the tents/canopies.
- 3. Tents or canopies with an occupant loading of more than 50 people shall submit a detailed floor plan to EH&S that indicates the means of egress, seating capacity, arrangement of seating, and location/type of any heating devices to be used.
- 4. Tents or canopies shall not be located within 20 feet of lot lines, buildings, other tents or canopies, parked vehicles or internal combustion engines/generators. For the purpose of determining required distances, support ropes and guy wires shall be considered as part of the tent or canopy. *Exception: Separation distance between tents and canopies not used for cooking is not required when the aggregate floor area does not exceed 15,000 square feet.*

Occupancy Load Requirements:

Tent/canopy occupancy loads are determined as follows:

- 1. Tents/canopies set up as a table and chair event (sit down meal) require 15 square feet per person.
- 2. Tents and canopies set up as a chaired event only require 7 square feet per person.
- 3. Tents/canopies set up without seating, for standing room only, require 5 square feet per person.

Exit Requirements:

- 1. Tent/canopy occupants must be within 100ft of an exit from any point in the structure.
- 2. Exit signs must be posted at each exit in a tent, and they must be either self-luminous, or capable of being illuminated by power.
- 3. The minimum width of an exit must not be less than 36 inches.
- 4. Guy wires or guy ropes must not cross an exit at a height of less than 7 feet.
- 5. Where tents/canopies are placed near fences or other obstructions, a clear exit path must be maintained to an area sufficiently away from the tent.
- 6. Tent/canopy stakes must be railed off, capped, or covered.

Flame Resistance and Structure:

- 1. All tent and canopy fabrics must be flame resistant.
- 2. A certificate or other proof of approval by a testing laboratory is acceptable as evidence of the required fire resistance. A copy of the certificate must be provided to EH&S. These certificates should be available from the tent supplier.
- 3. Tent suppliers must be able to certify that tents have been erected in accordance with manufacturer recommendations, industry standards, and code requirements.

Floor Covering:

 The area enclosed by any tent and not less than 10 feet outside of such tent must be cleared of all flammable or combustible material or vegetation prior to erecting the tent. The premises must be kept free from such flammable or combustible materials during the period for which the area is used. 2. No hay, straw, shavings, or similar combustible materials are permitted within any tent unless they have been treated to make them flame retardant. A certificate or other proof of approval by a testing laboratory indicating that the material has been properly treated is acceptable as evidence. A copy of certificates must be provided to the EH&S prior to placing such materials within a tent. These certificates are available from the material manufacturer or supplier.

Fire Protection:

- 1. At least one 10-pound ABC dry chemical fire extinguisher should be staged at each tent or canopy. Additional fire extinguishers may be required as occupancy increases or based upon materials utilized within the tent or canopy.
- 2. Commercial cooking equipment such as grills and broilers, when used within tents or canopies, must meet the same requirements for indoor commercial kitchens (i.e. proper ventilation, fire suppression systems).

Cooking and food warming issues:

- 1. Open exposed flames for cooking or other purposes are not permitted in tents or open canopies open to the public.
- 2. Food cooking operations using open/exposed flames must be staged at least 20 feet from tents/canopies used for assembly activities.
- 3. Food warming operations (using sterno or warming devices) are permitted in public assembly tents/canopies, but they should be set up with at least 10 feet clearance from any combustible material.

Electrical:

- 1. Electrical systems and equipment must be isolated from the public by proper elevation or guarding. All electrical fuses and switches must be enclosed in approved enclosures. Cables on the ground, in areas traveled by the public, must be placed in trenches or protected by approved covers (yellow jackets etc.).
- 2. All electrical systems must be properly grounded.
- 3. Generators must be placed at least 10 ft from tents and so that exhaust fumes do not enter tents.
- 4. Electrical installations must comply with the NFPA 70.

Propane Heating Systems:

- 1. Tanks shall be no closer than 10 feet to the tent/canopy.
- 2. All propane tanks shall be labeled.
- 3. All propane tanks shall be stored in the upright position.
- 4. Heating systems shall be installed in accordance with their listings.

8.1.5 Large scale Events

All events intended to, or that have the potential to, attract large crowd must be coordinated through multiple FAU departments and divisions. These include but are not limited to: University

Space Utilization and Analysis, FAU POLICE, Parking and Transportation, Physical Plant, Risk management, etc.

8.1.6 Fire and Life Safety Planning and Management Information

8.1.6.1 Room Capacity

Information on campus room capacities may be obtained from the University Space Utilization and Analysis. The State Fire Marshal Office determines the legal capacities. The occupant load is the maximum capacity based on the net clear floor area. Stages and other obstructions, seating arrangements and the use of tables will decrease the floor area. The type of event is also a determining factor.

The following are examples of occupant loads for areas that are frequently used:

Use	Area per person
Concentrated – (Auditorium and dance floor)	7 sq. ft./net
Less concentrated – no fixed seating (Conference room and classroom, gymnasium and dining lounge)	15 sq. ft.
Fixed seats	No. of fixed seats
Stage (persons on stage)	15 sq. ft
Kitchen	100 sq. ft. gross
Library (stack area)	100 sq. ft gross
Library (reading)	50 sq. ft gross
Swimming Pool (water surface)	50 sq. ft gross
Swimming Pool (deck area)	30 sq. ft gross

8.1.6.2 Exit Requirements

The placement of stages, seats, equipment (including wiring), and security arrangements affect exits and access to exits. Exits must remain unobstructed and provide clear access to the outside at all times. Wires or cables cannot be placed in front of exits or on steps, and must be properly taped down to the floor, or covered to avoid tripping hazards.

The number of exits required is based on room capacity.

Number of Persons	Minimum No. of Exits
≤ 49	1

Number of Persons	Minimum No. of Exits
50-100	2
101-600	3
601 or more	4

8.1.6.3 Set-up Plans

The FAU Boca Raton campus has standard set-up plans for the gymnasium, the Live Oak Pavilion, and the dining halls. Physical Plant, University Office of Space and Utilization, and respective facility operators maintain these plans and should be contacted. Set-up plans for other spaces not routinely used for public assembly (including lobbies and atriums), or any plans that are different from existing standard plans, must be approved in advance by University Office of Space and Utilization and the Office of the State Fire Marshal for conformance with life safety regulations. Temporary seats must be secured together. Temporary bleachers and platforms must be certified as structurally sound by a professional. The use of "festival" style seating (general admission without the use of actual seats) is prohibited for concert events in venues that have an occupant load of 1000 or greater (Gym, Live Oak etc.).

8.1.6.4 Expositions

Expositions of products or other displays have a number of special requirements. Contact the Office of Space Utilization and EH&S for consultation and event planning

8.1.6.5 Event Decorations

Decorations are common factors in the spread of fire. It is necessary to ensure that all decorations used meet the requirements of safety and fire resistance. All materials used for decorations and theatrical scenery, including the drop used behind stages during concerts must be class 'A' rated for flame spread. Sponsors, promoters, or other production personnel must have documentation that certifies the flame spread rating prior to the start of an event.

- Decorations cannot conceal or obstruct, in whole or part, exits, exit lights, fire alarm pull stations, fire hose cabinets, fire extinguishers, sprinkler heads, smoke detectors, or other fire related items.
- All decorations used in corridors, lobbies, assembly rooms, dining rooms, classrooms and offices must be non-combustible or flame retardant.
- If trees or plants (natural or artificial) are used, keep them out of corridors and away from doorways.
- Remove all decorations, wrappings and trees immediately after the event.
- No candles or open flame devices are permitted.
- Do not decorate corridors with wrapping paper.

8.1.6.6 Light Decorations

- Use only electric decorative lights and associated wiring for decorative lights that are UL or FM listed.
- Flame producing devices, such as but not limited to, candles are forbidden from use on all FAU campuses and buildings.
- Mixing and matching lights can create a fire hazard. Keep outdoor-rated lights outside and indoor-rated lights inside.
- Check the light bulbs, sockets, wires and plugs to make sure nothing is cracked, broken or exposed. Discard any defective light strands.
- Keep lights away from flammable and/or combustible materials.
- Extension cords used for temporary decorations must be UL listed.
- Do not connect more than three sets of lights to an extension cord.
- Keep all cords out of high-traffic areas where they could create a tripping hazard.
- Do not run cords through, under or behind a door, furniture or carpet. Such practice could lead to a fire.
- Electrical outlets shall not be overloaded.
- All lights shall be turned off before leaving the building.

8.1.6.7 Open Burning (Flames)

Open burning is defined as any open or exposed flame, whether indoors or outdoors, which could cause a potential fire hazard. Examples are bonfires, campfires, leaf burning, artwork involving flames, pyrotechnics of any kind, etc. The term open flame shall mean any flame or ember that may be able to come in contact with a flammable surface including but not limited to matches, gas or kerosene stoves/lamps, candles, sterno cans, cigarettes and flares. Open burning on any FAU property must be approved in writing by EH&S after consultation with the Office of the State Fire Marshal and the corresponding responding Fire Department.

8.1.6.8 Open Burning (Indoors)

Open burning indoors (particularly when such burning might activate any type of fire alarm detection/ suppression system) is normally prohibited. Special exceptions may be authorized under the following conditions.

- A written request is sent to EH&S at least two weeks in advance of the event.
- The proposed burning will not endanger the occupants of the facility.
- The burn location will not block any emergency device or access to exits.
- The event coordinator will contact EH&S, FAU POLICE, and the applicable building manager 24 hours in advance of the event for final coordination.
- The event coordinator will be responsible for providing a Fire Watch of the entire building during the time of the open burning if any safety system must be shut down.
- The event coordinator will be responsible for assigning event staff to monitor conditions in the burning area.
- The event coordinator will be responsible for complete extinguishing and removal of all materials.
- At the end of the burning, a thirty-minute watch will be made of the area to ensure there is no residual heat left in the material burned.

8.1.6.9 Open Burning (Outdoors)

Open burning outdoors will be authorized under the following conditions.

- A written request is sent to EH&S at least two weeks in advance of the event.
- The proposed burning will not endanger any adjacent building, vehicles or vegetation.
- The burn location will not block access for emergency vehicles to any building, street, or emergency device.
- Open flame fires will not be within fifty feet from any building, vehicle, or vegetation, or twenty-five feet from any flammable storage. The distance may vary according to the size of the event.
- The event coordinator will be responsible for providing Fire Guards in the burning area.
- The event coordinator will contact EH&S, Campus Police, and occupants of adjacent buildings 24 hours in advance prior to the event or operation for final coordination.
- The host will be responsible for complete extinguishing and removal of all materials used in the open burning.
- A minimum of a thirty-minute fire watch will be made of the area to ensure there is no residual heat left in the material.

8.1.6.10 Bonfires and Other Outdoor Fire Events:

For the purpose of this Fire Safety Manual a bonfire consists of a University Event organized and conducted under the responsibility of the Division of Student Affairs. An "outdoor fire event" is an event conducted by University student organizations, departments, units or third-party event organizers (referred to herein as "Sponsoring Organization") that request the use of an outdoor fire on University property or in conjunction with FAU-related events. Any outdoor fire event must utilize an EH&S approved portable outdoor fireplace or a commercially-designed chiminea. Portable outdoor fireplaces or chimineas must be elevated off of ground surface and must have an installed screen to prevent embers from escaping.

If a bonfire or other outdoor fire event is planned on University property or in connection with a university sponsored event, a review of the plan must be conducted by appropriate university departments and local authorities having jurisdiction (AHJs). Associated AHJ include, but is not limited to, the State Fire Marshal and the responding Fire Department.

Primary responsibility for the conduct of the event and the safety of participants, spectators and others, as well as obtaining permits from different entities resides with the Division of Student Affairs for a bonfire and with the Sponsoring Organization for an outdoor fire event. All departments or organizations wishing to have a bonfire or other outdoor fire event, must work through the Division of Student Affairs. EH&S has authority to reject authorization of the bonfire and at any time withdraw authorization if there are changes in plans, conflicts with applicable regulations, or concerns with public safety.

For bonfires, the Division of Student Affairs (DSA) will complete the following items:

- 1. The DAS is the agency that is responsible for bonfire events at FAU and shall ensure:
 - a. that the bonfire plan adheres to applicable regulations, codes, ordinances and other university policies and procedures, including obtaining appropriate permits and licenses as require;

- b. that all costs associated with the bonfire including, but not limited to permits, access control, debris removal, ground/landscaping restoration, crowd control, security, fire department brush truck fees, etc are accounted for and paid;
- c. bonfire debris removal is completed which includes, but is not limited to, the removal of all litter at the bonfire site, all remnants of the fire, unburned wood, nails, etc., and
- d. that ground/landscaping restoration, including restoring the bonfire site to its original condition with the resodding of all affected areas with the same type of grass, is completed.
- 2. The DSA shall submit the request for bonfire 60 business days prior to the event, to allow ample time to review the plans, engage necessary resources, and obtainment of any State or local permits, by submitting a Facilities Use Application (FUA) to the Office of Space and Utilization for review and approval. The FUA shall include the following items:
 - a. A narrative describing the scope, purpose, and location of the bonfire including a map of the exact location and a plan for protecting safety and security.
 - b. Identify the DSA team and their associated responsibilities that will include at a minimum:
 - promotion of the bonfire event it to the FAU community, especially to the student body;
 - ii. the set-up of the bonfire, the removal of excess wood and debris from the bonfire site once construction of the bonfire is completed;
 - iii. that fuel for the bonfire only consists of seasoned dry fire wood and other untreated wood products, such as pallets or nail free construction debris. No pressure or chemically treated (i.e. pressure treated) wood may be used.
 - iv. establishing a secure zone not less than 100 feet from the base of the fire with only members of the local fire rescue department and other persons assigned crowd control duties being permitted entry.
 - c. That the DSA Team will conduct the bonfire as follows:
 - i. only a member of the local fire department present at the event shall ignite the bonfire;
 - ii. that the bonfire shall be ignited using a ≥60-inch torch/stick with the lighting object being secured to the torch/stick;
 - iii. that no accelerants (gasoline, charcoal lighter fluid, kerosene, diesel fluid) or any other flammable is used to start the bonfire.
 - iv. that with the lighting location will position the person with the wind at their back at the time;
 - v. the bonfire shall not be scheduled to burn more than two hours and if conditions warrant, the fire may be extinguished at any time by the local fire rescue department to ensure public safety; and
 - vi. shall ensure that the size of the bonfire does not exceed 6 feet high and 10 feet in radius and is constructed in a safe manner. Burning articles in effigy must be approved during the planning process and no additional fuel shall be added once the fire starts burning.

8.1.6.11 Fireworks, Pyrotechnics and Flame Effects

This Section establishes the standards for approval, use of fireworks and other incendiary devices. University student organizations, departments, units or third party event organizers that request the use of fireworks, pyrotechnics or flame effect displays on University property or in

conjunction with FAU-related events are hereafter referred to as the "sponsoring organization" and must successfully complete the authorization process detailed below.

These requirements and procedures set forth the standards and responsibilities for the application and approval of the use of displays of pyrotechnics and/or flame effects at Florida Atlantic University, including but not limited to, sporting events, ceremonies, conferences, banquets, science demonstrations, parades, theatrical or concert performances. For purposes of this Section, the following items are defined as follows:

- **Fireworks**: Any composition or device for the purpose of producing a visible or audible effect for entertainment purposes by combustion, deflagration, or detonation that meets the definition of *Consumer Fireworks* or *Display Fireworks* as set forth in NFPA Standard 1123. Fireworks are for outdoor use.
- **Pyrotechnics**: Controlled exothermic chemical reactions that are timed to create the effects of heat, gas, sound, dispersion of aerosols, emission of visible electromagnetic radiation, or a combination of these effects to provide the maximum effect from the least volume. as defined in NFPA Standard 1126.
- Pyrotechnics Device: Any device containing pyrotechnic materials or pyrotechnic effect simulation equipment, as described in NFPA Standard 1126 and capable of producing a special effect as per NFPA Standard 1126. Pyrotechnics for proximate audience are for indoor use.
- Flame Effects: The combustion of flammable solids, liquids, or gases to produce thermal, physical, visual, or audible phenomena before an audience as defined in NFPA Standard 160. Flame effects can be for indoor or outdoor use.

The display operator is a licensed person or company responsible for the operation and safety of displays as contracted by the sponsoring organization. A display operator must hold a valid pyrotechnics license from a state that Florida Atlantic University recognizes as a credible licensing authority. Only individuals licensed to handle fireworks, pyrotechnics or flame effect displays will be approved. The individual or company responsible for transportation of display materials must have a valid Bureau of Alcohol, Tobacco, Firearms and Explosives (ATF) card and be in compliance with U.S. Department of Transportation (DOT) requirements.

The sponsoring organization is the organization (i.e. university student organization, departments, units or third-party event organizers) that is responsible for contracting with an authorized display operator to provide fireworks, pyrotechnics and/or flame effects.

In accordance with the policies and procedures of FAU, all display operations must be adequately insured. The display operator must carry insurance and provide an insurance certificate with the required limits and with a company that is acceptable to the University Risk Manager. The required insurance certificate is to be delivered to the university within seven (7) days prior to the scheduled event; otherwise the event may be cancelled at the University's discretion.

All requests for displays on FAU property or in conjunction with an FAU-related event must be submitted to EH&S at least six weeks prior to the event and must be approved by the:

- University Risk Manager,
- Office of Event Management and/or Department of Space Utilization & Analysis,
- FAU Police, and
- State Fire Marshall.

Only the Display Operator's pyrotechnics technicians and licensed staff shall handle and launch the pyrotechnics. Use of remote ignition systems that are not under the direct control of the onsite operators shall not be permitted.

The Sponsoring Organization must complete either a Request for Use of Pyrotechnics Before a Proximate Audience (Appendix 3) or Request For Use of Flame Effects Before an Audience (Appendix 4) and submit to EH&S as part of the FUA submittal to the Department of Space Utilization & Analysis. Organizations are responsible for understanding and abiding by the applicable policies and procedures. In addition, the Sponsoring Organizations must:

- Provide the potential display operator with FAU insurance requirement information,
- Arrange for FAU Police to provide services for the display,
- Provide for adequate cleanup of the display site within 24 hours of the display and return site to its pre-event condition,
- Obtain and provide EH&S with a copy of the potential display operator's applicable licenses, certificate of insurance, and material safety data sheets for the products(s) being used.
- Obtain and provide EH&S with a copy of the potential display operator's process to remove and disposal of by-products from displays,
- Assume responsibility for the performance of a post-display inspection of exterior grounds or interior areas by the potential display operator to confirm no unexploded devices or debris remain,
- Assume sole responsibility for the disposal of such by-products from displays by the
 potential display operator are in compliance with Federal, State and University
 requirements.

EH&S and FAU POLICE Will review display application, diagram of the display/ shooting area and any specific requirements related to the display and coordinate approval with the local authorities having jurisdiction.

University Risk Manager will review and approve display operator's certificate of insurance and assess the risk associated with each event and provide information to EH&S.

Office of Event Management/Space Utilization & Analysis Will authorize the use of the facility or property after ensuring proper documents are on file (i.e. Facilities Use Agreement).

9 STORAGE FIRE SAFETY

Storage shall include all spaces or structures used primarily for the storage or sheltering of goods, merchandize and records and products.

Storage in itself does not constitute a fire hazard. A fire hazard is created when items are stored improperly, in a hazardous location, or block egress and/or exits.

9.1 General Storage

 Combustible materials must be separated from other hazardous materials such as flammables, corrosives, explosives, oxidizers etc. Contact EH&S for approval of separations.

- Storage areas must be separated from other areas by at least a one-hour fire barrier with a fire rated self-closing door, and be protected by fire detection and/or suppression systems.
- Stored materials must be kept at least thirty-six inches from any heat source.
- Aisles in storage rooms must have a minimum width of twenty-eight inches to allow for evacuation, and permit firefighters to gain access to the most remote area of the room.
- Storage cannot block fire extinguishers, fire alarm pull stations, emergency or exit lighting, access to evacuation routes or the exit door, emergency equipment or prevent entry of emergency personnel.
- Storage under stairs is not permitted unless the area is enclosed and protected with a one-hour fire rated enclosure and a detection and/or suppression system.
- Doors to storage rooms may not be "propped" open at any time.
- Contact Property Management for proper disposal of and storage of surplus, obsolete and unused property.
- Smoking is not permitted in any storage area under any conditions.

9.2 Flammable Storage

It is critical that flammables are used and handled properly and stored safely.

- Rooms used for flammable storage must be constructed to meet the requirements for at least one-hour fire rating, ventilation, heating, electrical systems, fire detection and/or suppression systems.
- Flammables generally are not permitted to be stored in basements of buildings. Exceptions will be determined by EH&S and must be authorized in writing.
- A "daily use" of flammable liquids may be stored on open shelves. "Daily use" refers to a small amount of consumable flammables that are expected to be used in a repetitive nature, and the amount used would not constitute more of a hazard than other ordinary combustibles in the room. Store flammable materials not in active use in an approved flammable storage cabinet.
- Flammables, required to be stored away from combustibles, will be stored in an approved flammable storage cabinet. This cabinet will be labeled and incorporate self-closing doors.
- Flammable storage will be kept at least 50 feet from open flames or other heat sources.
- Oily or grease-laden rags must be placed in a self-closing oily rag can for proper cleaning or disposal.
- Ordinary combustibles may not be stored in flammable storage.

9.3 High Stack Storage

This type of storage has become increasingly popular for space saving purposes for records and commodities. This also presents a different type of hazard for fire safety and firefighting.

- The construction of storage racks should utilize -combustible materials to reduces the amount of fire spread should a fire occur.
- Under no circumstances may storage of materials be closer than eighteen inches of sprinkler heads.

- Aisle widths in high rack storage, which also requires the use of mechanical devices such as forklifts or carts, must be of sufficient width to allow personnel evacuation if a forklift/cart is in the aisle.
- Collect hazardous waste in appropriate containers.

9.4 Housekeeping, Maintenance, and Protection of Storage Spaces

- The structural integrity of racks used for storage shall be properly maintained.
- Records storage height must not exceed the nominal 15 feet.
- Hot work around storage structure shall be highly regulated.
- Storage areas aisles shall be kept clear from storage of waste material and debris.
- Fire doors shall not be obstructed.
- All record storage and adjoining areas must be protected by a professionally designed fire detection and suppression system.
- The position of sprinkler heads must provide complete, unobstructed coverage, with clearance of not less than 18 inches.
- Two-hour fire barrier walls must be provided between the record storage areas and other auxiliary places and 3-hour fire barrier wall separating storage areas from each other.
- The fire resistive rating of the roof must be a minimum of half hour for all records storage facilities.

10 ELECTRICAL FIRE SAFETY

Electricity is a serious work place hazard, capable of causing employee death and injury as well as serious property damage. This program establishes minimum standards to prevent hazardous electrical exposures to personnel and ensure compliance with regulatory requirements applicable to electrical systems. It is also intended to protect employees against electrical shock, burns and other potential electrical safety hazards such as fire and explosion as well as comply with regulatory requirements.

Management is responsible for providing employees safety training, conducting electrical safety inspections, correcting all electrical safety hazards and that all electrical equipment and components comply with code and regulations. Employees are responsible for the immediate reporting of electrical safety hazards, for not working on electrical equipment without proper training and authorization for complying with all electrical safety rules and regulations and inspecting equipment before using it.

10.1 Electrical Hazards Control

10.1.1 Engineering Controls

- All electrical distribution panels, breakers, disconnects, switches and junction boxes must be completely enclosed.
- Water tight enclosure must be used if any of these components could possibly be exposed to moisture.
- Structural barriers must be used to prevent accidental damage to electrical components.
- Conduits must be supported through their entire length, and non-electrical attachments to conduits are prohibited.

Non-rigid electrical cords must have strain relief wherever necessary.

10.1.2 Administrative Controls

- Only trained, authorize employees may repair or service electrical equipment.
- Contractors must be licensed to perform electrical work.
- Physical barriers must be used to prevent unauthorized persons from entering areas where new installations or repair of electrical components or equipment is being performed.
- Only authorized personnel may enter electrical distribution rooms.
- All electrical control devices must be labeled properly.
- Senior facility manager must authorize any work on energized electrical circuits.
- Inspect all electrical equipment for hazards that could cause employee injury, death.

10.1.3 Personal Protective Equipment

- Management will provide personal protective equipment (PPE) for use and its use is mandatory when there is the potential for contact with exposed electrical sources.
- Inspect and test PPE before use.
- Wear non-conductive headgear if there is danger of electrical burns or shock from contact with exposed energized equipment.
- Wear eye and/or face protection any time there is danger of flying objects, flashes or electrical arcs produced by an electrical explosion

10.1.4 Training Requirements

Workers near energized, or potentially energized electrical circuitry of fifty (50) volts to ground or greater, shall be trained in energized electrical safe work practices and procedures and retrained as necessary.

10.1.5 Qualified Electrical Worker

Prior to performing energized electrical work, employees must receive training in avoiding electrical hazards associated with working on, or near, exposed energized parts. Such training will be provided when the employee is initially assigned to the job and refresher training will be provided every three years or when conditions change.

The following items are to be included in the training of Qualified Electrical Workers:

- Demonstrate a working knowledge of the National Electrical Code.
- Familiar with lockout/tag-out procedures including safe work practices required to safely de-energize electrical equipment.
- Universal electrical safety procedures.
- Skills and techniques necessary to distinguish exposed live parts from other parts of electric equipment.
- Perform on-the-job training with a qualified electrical worker.
- Skills and techniques necessary to determine the nominal voltage of exposed live parts.
- Selection and use of proper work practices, personal protective equipment, tools, insulating and shielding materials and equipment for working on or near energized parts.

10.1.6 Portable Electrical Equipment and Extension Cords

The following requirements apply to the use of cord-and-plug-connected equipment and flexible cord sets (extension cords):

- Extension cords may only be used to provide temporary power.
- Portable cord-and-plug connected equipment and extension cords must be visually inspected before use, every shift, for external defects such as loose parts, deformed and missing pins, damage to outer jacket or insulation, and for possible internal damage such as pinched or crushed outer jacket. Any defective cord or cord-and-plug connected equipment must be immediately removed from service and no person may use it until it is repaired and tested to ensure it is safe for use.
- Extension cords must be of the three-wire type. Extension cords and flexible cords must be designed for hard or extra hard usage.
- Personnel performing work on renovation or construction sites using extension cords or where work is performed in damp or wet locations must be provided, and must use, a ground-fault circuit interrupter (GFCI).
- Portable equipment must be handled in a manner that will not cause damage. Flexible electric cords connected to equipment may not be used for raising or lowering the equipment.
- Extension cords must be protected from damage. Sharp corners and projects must be
 avoided. Flexible cords may not be run through windows or doors unless protected from
 damage, and then only on a temporary basis. Flexible cords may not be run above ceilings
 or inside or through walls, ceilings or floors, and may not be fastened with staples or
 otherwise hung in such a fashion as to damage the outer jacket or insulation.
- Cords must be covered by a cord protector or tape when they extend into a walkway or other path of travel to avoid creating a trip hazard.
- Attachment plugs and receptacles may not be connected or altered in any way that would interrupt the continuity of the equipment grounding conductor. Additionally, these devices may not be altered to allow the grounding pole to be inserted into current connector slots. Clipping the grounding prong from an electrical plug is prohibited and damaged/altered cords must be immediately removed from service.
- Flexible cords may only be plugged into grounded receptacles. The continuity of the ground
 in a two-prong outlet must be verified before use. It is recommended that the receptacle
 be replaced with a three-prong outlet. Adapters that interrupt the continuity of the
 equipment grounding connection may not be used.
- All portable electric equipment and flexible cords used in highly conductive work locations, such as those with water or other conductive liquids, or in places where employees are likely to contact water or conductive liquids, must be approved for those locations.
- Employee's hands must be dry when plugging and unplugging flexible cords and cord-andplug connected equipment if energized equipment is involved.
- Lamps for general illumination must be protected from breakage, and metal shell sockets must be grounded.
- Temporary lights must not be suspended by their cords unless they have been designed for this purpose.
- Portable lighting used in wet or conductive locations, such as tanks or boilers, must be
 operated at no more than 12 volts or must be protected by GFCI's.

• Extension cords are considered to be temporary wiring, and must also comply with the section on "Requirements for Temporary Wiring" in this program

10.1.7 Requirements for Temporary Wiring

Temporary electrical power and lighting installations 600 volts or less, including flexible cords, cables and extension cords, may only be used during and for renovation, maintenance, repair, or experimental work. The duration for temporary wiring used for decorative lighting for special events and similar purposes may not exceed 90 days. The following additional requirements apply:

- Ground-fault protection (e.g., ground-fault circuit interrupters or GFCI) must be provided on all temporary-wiring circuits, including extension cords, used on construction sites.
- In general, all equipment and tools connected by cord and plug must be grounded. Listed or labeled double insulated tools and appliances need not be grounded.
- Feeders must originate in an approved distribution center, such as a panel board, that is rated for the voltages and currents the system is expected to carry.
- Branch circuits must originate in an approved power outlet or panel board.
- Neither bare conductors nor earth returns may be used for the wiring of any temporary circuit.
- Receptacles must be of the grounding type. Unless installed in a complete metallic raceway, each branch circuit must contain a separate equipment-grounding conductor, and all receptacles must be electrically connected to the grounding conductor.
- Flexible cords and cables must be of an approved type and suitable for the location and intended use. They may only be used for pendants, wiring of fixtures, connection of portable lamps or appliances, elevators, hoists, connection of stationary equipment where frequently interchanged, prevention of transmission of noise or vibration, data processing cables, or where needed to permit maintenance or repair. They may not be used as a substitute for the fixed wiring, where run through holes in walls, ceilings or floors, where run through doorways, windows or similar openings, where attached to building surfaces, or where concealed behind building walls, ceilings or floors.
- Suitable disconnecting switches or plug connects must be installed to permit the disconnection of all ungrounded conductors of each temporary circuit.
- Lamps for general illumination must be protected from accidental contact or damage, either
 by elevating the fixture or by providing a suitable guard. Hand lamps supplied by flexible
 cord must be equipped with a handle of molded composition or other approved material
 and must be equipped with a substantial bulb guard.
- Flexible cords and cables must be protected from accidental damage. Sharp corners and projections are to be avoided. Flexible cords and cables must be protected from damage when they pass through doorways or other pinch points.

10.1.8 Working on Wet or Damp Locations

Work in wet or damp work locations (i.e., areas surrounded or near water or other liquids) should not be performed unless it is absolutely critical. Electrical work should be postponed until the liquid can be cleaned up. The following special precautions must be incorporated while performing work in damp locations:

- Only use electrical cords that have Ground Fault Circuit Interrupters (GFCIs);
- Place a dry barrier over any wet or damp work surface;
- Remove standing water before beginning work. Work is prohibited in areas where there is standing water;
- Do not use electrical extension cords in wet or damp locations; and
- Keep electrical cords away from standing water.

10.1.9 Working on De-Energized Equipment

10.1.10 Electrically Safe Condition

The most important principle of electrical safety is to assume all electric circuits are energized unless each involved worker ensures they are not. Every circuit and conductor must be tested when work is done on them. Proper PPE must be worn until the equipment is proven to be deenergized.

- Voltage-rated gloves and leather protectors must be worn
- Electrically insulated shoes should be worn
- Approved insulating mats
- Safety glasses must be worn
- The required Arc Flash PPE must also be worn

The process of de-energizing is "live" work and can result in an arc flash due to equipment failure. When de-energizing equipment, follow the procedures specified in the EH&S Policy and Procedure #7 University Lockout/Tagout Policy (https://www.fau.edu/ehs/policies-and-procedures/ehs07-lockout-tagout.pdf)

10.1.11 Working Space around Electric Equipment

10.1.11.1 Spaces around Electrical Equipment

- Sufficient access and working space shall be provided and maintained around all electric
 equipment to permit ready and safe operating and maintenance of such equipment.
 Enclosures that house electric apparatus and are controlled by lock and key shall be
 considered accessible to qualified persons.
- Width of Working Space. The width of the working space in front of the electrical equipment shall be the width of the equipment or 750 mm (30 in), whichever is greater. In all cases, the work space shall permit at least a 90-degree opening of equipment doors or hinged panels.
- Height of Working Space. The workspace shall be clear and extend from the grade, floor, or platform to the height required by 70E 400.15(E). Within the height requirements of this section, other equipment that is associated with the electrical installation and is located above or below the electrical equipment shall be permitted to extend not more than 150 mm (6 in) beyond the front of the electrical equipment.
- Clear Spaces. Working space required by the 70E standard shall not be used for storage. When normally enclosed live parts operating at 50 volts or more are exposed for inspection or service, the working space, if in a passageway or general open spaced shall be suitably guarded.

10.1.11.2 Access and Entrance to Working Space

- **Minimum Required**. At least one entrance of sufficient area shall be provided to give access to the working space about electric equipment.
- **Unobstructed Exit**. Where the location permits a continuous and unobstructed way of exit travel, a single entrance to the working space shall be permitted.

10.1.11.3 Illumination

Illumination shall be provided for all working spaces about service equipment, switchboards, panel boards, or motor control centers installed indoors. Additional lighting outlets shall not be required where the work space is illuminated by an adjacent light source. In electrical equipment rooms, the illumination shall not be controlled by automatic means only.

10.1.11.4 Headroom

The minimum headroom of working spaces about service equipment, switchboards, panel boards, or motor control centers shall be 6 1/2ft). Where the electrical equipment exceeds 6 1/2 ft. in height, the minimum headroom shall not be less than the height of the equipment.

10.1.11.5 Dedicated Equipment Space

All switchboards, panel boards, distribution boards, and motor control centers shall be located in dedicated spaces and protected from damage.

10.1.12 Contractor Employees

- Electrical safety programs used by contractors must meet or exceed all applicable guidelines of this Program.
- Contractors are required to comply with applicable Safety and Health regulations such as OSHA, NFPA, and EPA.
- Contractors may be required to submit copies of their safety program to the safety coordinator upon request.

10.1.13 Electrical Fire Prevention Tips

- Electrical work shall be done only by a qualified electrician.
- Keep light fixtures and light bulbs away from anything that can burn, including furniture, bedding, curtains, clothing, and flammable or combustible gases and liquids.
- Use light bulbs that much the recommended wattage on the lamp or fixture.
- If a fuse blows or a circuit breaker trips often find out why and correct the problem. Have a qualified electrician inspect and fix it.
- Always replace blown fuses with ones on the proper rating. If the problem continues, call electrician.

- Major appliances (refrigerators, stoves, washers, dryers) should be plugged directly into a
 receptacle outlet. Never use an extension cord with a major appliance as it can overload
 the cord and cause the flexible covering to catch fire.
- Check electrical cords often. Replaced cracked, damaged and loose electrical or extension cords.
- Avoid putting cords where they can be damaged or pinched by furniture, under rugs and carpets, or across doorways.
- Use only surge protectors or power strips that have internal overload protection. Use surge protectors or power strips that have the label of a recognized testing laboratory.
- Extension cords are for temporary use only. Have a qualified electrician determine if additional circuits or outlets are needed.
- Replace outlets if plugs fit snugly or the outlet does not accept plugs with one blade larger than the other.
- Cover outlets and wall switches with wall plates to prevent shocks.
- Ground fault circuit interrupters (GFCI) reduce the risk of shock. GFCI shut off electricity
 when it becomes a shock hazard. Make sure GFCIs are installed in bathrooms, basements,
 garages, outdoors, at kitchen counters and in other locations in the home where electricity
 is near water.

11 FIRE SAFETY PROGRAM IN THE RESIDENCE HALLS

11.1 Residence Hall Fire Safety Program Objectives

The primary objective of the campus Resident Hall fire safety program is to prevent fire and take appropriate actions before such conditions result in a fire emergency. This goal is accomplished by:

- Conducting periodic reviews and updates of fire prevention policies.
- Conducting regularly scheduled fire drills.
- Promoting fire prevention and emergency evacuation procedures.
- Inspecting, testing and maintaining fire protection systems in accordance with NFPA standards.
- Performing plan reviews and code consultation related to capital improvement and remodeling projects.
- Mitigating fire hazards utilizing the information provided from regularly scheduled fire safety inspections performed by the Office of the State Fire Marshal, EH&S as well by the department of Housing and Residential Life and other fire protection consultants.
- Raising awareness of residents in fire safety.

11.2 On-Campus Student Housing Fire Protection Equipment and Systems

Specially designed systems are provided in all Residence Halls to assist in extinguishing fires and to limit the spread of fire and smoke by either automatic, semi-automatic or manual means. These include, but are not limited to:

- Portable fire extinguishers,
- fire hoses,
- fire pumps,

- wet and dry stand pipe systems,
- automatic sprinklers,
- specially engineered suppression systems,
- fire detection and alarm systems,
- fire doors,
- and fire dampers.

Other life safety systems, including exit and emergency lights with back-up emergency power, are integral parts of the residence hall fire protection systems. Fire protection and life safety equipment are installed inspected, tested and maintained in accordance with NFPA Codes and as required by the local AHJ.

11.3 Fire Prevention Policies and Procedures:

Several fire prevention policies and procedures have been developed and implemented. Applicable NFPA, FAU Fire Safety Program, FAU safety policies and procedures, Housing and Residential Life Regulations, and the FAU Crisis Action Guide were referenced during the development of these policies. A summary of these policies is highlighted bellow.

11.3.1 Policy on Holiday Decorations

- All decorations and ornaments must be of fire-resistant or non-combustible material, and listed by Underwriters Laboratory (UL) and approved for use.
- The use of live or cut Christmas trees is prohibited in all university buildings and spaces.
- Artificial trees made of fire-retardant materials or non-combustible materials labeled with UL or Factory Mutual (FM) approval ratings are allowed. No natural trees, wreathes, boughs or other decorations constructed from the branches of natural trees may be used.
 Metallic trees may create electrical hazards when placed in close proximity to the electric supply; therefore, the use of electric lights on metallic trees is prohibited.
- Trees and other decorations must be located so as not to obstruct exit corridors or the operation of fire protection equipment. Trees should also not be placed in any manner that could present a fall or trip hazard, impede egress, or block emergency egress from any room.
- Electrical cords shall not be routed through or under doors, rugs or loose carpeting or across work surfaces. Routing of cords through these areas may cause damage to the cord and create a fire or trip hazard.
- Plugging lights into an overloaded circuit is not permitted and the use of multiple adaptors is prohibited. Instead, use power strips with a fuse or integral circuit breaker when extra outlets are needed.
- Decorative displays are prohibited in stairwells and should be limited in lobbies and common areas in the residence halls.
- All holiday decorations should be removed before leaving campus for the holiday and at the end of each semester.
- No candles, incense burners, potpourri pots, or scented oil warmers may be used.
- Decorative materials like paper or cloth or any other type of combustible materials shall not cover more than 20% of hallway or rooms walls.

11.3.2 Policy on Electrical Equipment and Appliances

Indoor cooking is possible in the community kitchens in the residence halls. Kitchens in all residence halls are not designed to be primary cooking areas with exceptions at University Village and Innovation Village Student Apartments where individual apartment units are intended for primary cooking. Only low wattage appliances which do not produce grease, smoke laden vapors, and that have no open elements are permitted in University Housing. Prohibited fire or life safety hazards include but are not limited to the following:

- · Alcohol stoves, propane grills, hibachis and gas grills
- Refrigerators exceeding 400 watts
- Microwaves exceeding 1100 watts
- Rice cookers
- Hamburger cookers
- Frying skillets
- Barbeque grills
- 110 volts extension cords
- 110 volts extension cords wrapped in duct tapes
- Piggy backed power strips
- Duct tape wrapped around electrical plugs
- Electrical outlet with no cover plates
- Any halogen lamp that requires a bulb over 120 volts
- Space heaters
- The use or storage of flammable fluid, hazardous liquids or chemicals.

11.3.3 Policy on Electrical Safety

EXTENSION CORDS are acceptable means of providing **TEMPORARY** power. However, they cannot be used as a substitute for permanent electrical wiring. They can be used provided they are:

- Used temporarily
- Used to power non-heat producing devices
- UL approved and Factory Manual listed and three-wire grounded.
- Not connected, spliced together, or piggy-backed
- Plugged into a permanent outlet

EXTENSION CORDS WILL NOT BE PERMITTED:

- When used as permanent wiring
- When used on heat producing or high voltage devices such as heaters, microwave ovens, refrigerators etc.
- If they become a tripping hazard
- When routed through openings in walls, ceilings, doorways or under flooring or carpets etc.
- When showing signs of wear, defects, bulging, exposed wire or other damages
- When plugged into a power strip or another extension cord.

11.3.4 Policy on Tampering

- Tampering with or damaging fire safety equipment including automatic door closures, smoke detectors, pull stations, fire extinguishers, sprinkler heads is punishable by law.
- Initiating false alarms, stopping existing fire alarms, or failing to immediately evacuate during a fire alarm are violation of state fire codes, and will result in disciplinary action and are punishable under state law.

11.3.5 Candle and Open Flame Safety

Possession or use of candles, open flames, incense, hot plates and heating units with open flame or heating element are prohibited.

11.3.6 Cooking Safety

The leading cause of kitchen fires is unattended cooking, when the food or liquid overheats and catches fire. Cooking is permitted only in approved outside areas and in-residence halls that have designated cooking facilities.

While cooking students are advised through established policies to:

- Stay near the stove or in the room at all times when cooking.
- If leaving the room is necessary, remove the food from the heat and turn off the stove.
- Keep all loose material and objects that can catch fire, including clothing, away from all heat sources and the stove.
- Keep the oven, stove, toaster, and grill clean as a buildup of fat, crumbs, or grease can easily catch fire.
- Keep all metal or metallic items out of microwaves.
- Residents are responsible for proper use of cooking appliances.
- In the Village Student Apartments and Innovation Village Student Apartments, residents are permitted to use personal charcoal barbeque grills at a safe distance (at least 20 feet or more) from buildings and entrances. Use of personal grills are not permitted in the Residence Halls or on the grounds of the Residence Hall area.
- The use of grills is not permitted under any covered walkways landings, entrances, balconies or stairwells that include the main breezeway.

11.3.7 Policy on Smoking Safety

Smoking is not permitted inside any of the residence halls, including student rooms, hallways, bathrooms, elevators, lounges dining areas and other public areas in compliance with the Florida Clean Indoor Air Act.

11.3.8 Policy and Procedure on Fire Drills

Fire drills are an intricate part of FAU's emergency preparedness planning and are conducted in a manner to educate residents and to ensure compliance with the laws of the State of Florida.

Residence Halls fire drills are coordinated by Housing and Residential Life, EH&S, as well as FAU POLICE. Students living in the Residence Halls are required to participate in fire drills.

During student orientation, or in other forums used to raise awareness, students staying on campus housing are reminded or informed about fire drills and what to do during a fire emergency. Four fire drills are scheduled in each Residence Hall during the academic year as described below:

- Fall Semester (1)
- Spring Semester (1)
- Summer Semester (2)

One fire drill within the first three weeks of each of the fall and spring semesters and another two drills in summer semesters is conducted. Notifications are posted in each residence hall approximately 48 hours in advance of the fire drill.

Students are to evacuate when the fire alarm is activated and proceed to a predetermined assembly area away from the building. Failure to do so will result in disciplinary action of a \$75.00 fine. Elevators shall not be used during fire drill evacuations.

Prior arrangement shall be made to assist handicapped occupants. Resident Assistants will be assigned on each floor to ensure students are evacuating at the sound of the alarm. Once an "all cleared" signal is given to the building coordinator, the fire alarm will be silenced, reset, and occupants may be permitted to re-enter the building.

FAU EH&S and Safety monitors the effectiveness of the drills and documents them, while the FAU Police Department assists in crowd management and communication with Police Dispatch to ensure fire alarm activation and reset signals are monitored.

Fire drills are conducted and documented in accordance with the FAU fire drill policy.

11.3.9 Emergency Evacuation Procedures

In the event of fire, bomb threat, hazardous material spill, etc., students are instructed to adhere to the following procedures:

- 1. Activate fire alarm system if it is not already activated.
- 2. Evacuate the building using the nearest exit or exit stairways and close door behind you as you leave. **DO NOT USE ELEVATORS**.
- 3. Call 911 from a safe location and provide name, location and nature of emergency.
- 4. Proceed to the common assembly area of the building.
- 5. Stay out until you are told to re-enter the building.

11.3.10 Fire Alarm Reporting and Evacuation Protocols

If a fire alarm sounds in a building the Resident Assistants (RA) will report to the area office immediately. The RA on duty will assume leadership for implementing the emergency protocol and the rest of the RAs will be distributed on different levels and at exit ways to assist with crowd control and expedite evacuation.

FAU POLICE dispatches the local fire department to the scene and after investigation of the incidence, the alarm is silenced.

Once the alarm has been silenced and the fire department or police has given the all clear signal, the Resident Coordinator will have the RA on duty notify the rest of the RAs around the building

that students are permitted to enter. No student will be permitted to enter the building until this has occurred.

The Resident Coordinator will then fill out appropriate paper work. The Resident Coordinator (RC) of the building or the assistant director and the director will get involved depending on the nature of the emergency. If the emergency is categorized to be a disaster the emergency operation center is activated and the FAU community and other stakeholders are informed using the emergency alert system.

11.3.11 Policy on Fire Safety Inspections

Housing and Residential Life, as well as EH&S take proactive measures to foster students' cooperation and compliance with fire safety requirements. Residence Assistants and EH&S personnel conduct Fire safety inspections of the Residence Halls, including student rooms, as needed. Monthly inspections of fire extinguishers, exit signs and egress pathways are also conducted. The State Fire Marshal inspects Residence Halls on an annual basis. The State Fire Marshal inspection gives FAU the ability to address and mitigate any life safety violations identified by the inspector before the start of the fall semester.

If unapproved items or practices are discovered during inspections, immediate action will be taken to remove the hazards or discontinue the practice.

11.3.12 Policy on Fire Safety Education and Training

Florida Atlantic University's fire safety program themes are fire prevention, emergency preparedness, and evacuation (response). Training requirements for FAU Housing Staff, is detailed in Section 3.2.

Fire prevention and fire response trainings are on-going awareness programs that focus on the elimination of fire hazards and what to do in case of a fire (i.e. **EVACUATION**).

Basic fire safety instruction is provided to all students living in residence halls who attend the orientation programs the beginning of each academic year.

In addition to the training workshops, FAU EH&S and the Housing staff also distribute fire safety information to students on a regular basis, especially using venues like Safety Month and the Annual Fire Prevention Week.

11.3.12.1 Fire Prevention Training

Fire prevention training includes instructions on what should be done to reduce the potential for ignition and fuel loads. Participants are trained to recognize potentially hazardous situations such as smoking, about open flames and candles as well as cooking fires including poor housekeeping practices

11.3.12.2 Fire Response Training

This training includes clear instructions on what residents should do in the event of a fire. Emphasis is made on getting out of the building at the sound of the alarm. Since small fire can be fought successfully with portable fire extinguishers participants are also trained how to use a fire extinguisher as well as how to recognize when a fire is too large to attack. Participants are instructed to observe the rules for safe evacuation and to practice periodically through fire drills.

Each Resident is given a copy of the Housing and Residential Education Community Guide that provides information on a variety of fire safety issues and what appropriate action to take during a fire alarm or fire emergency including instructions:

- 1. Not to tamper with the building fire protection features, either intentionally or accidentally.
- 2. Not to cover Smoke detectors or have the batteries removed.
- 3. Not to hang any object from a sprinkler head or be subjected to physical abuse.
- 4. Not to store objects in exit ways, including hallways, corridors and stairways, where they could obstruct egress path.
- 5. Know how to report fires etc.
- 6. What items are not allowed to bring in to their rooms
- 7. Hazards associated with the use of electricity and electrical cords.

12 FIRE EXTINGUISHER PROGRAM

Fire extinguishers are special pressurized devices that release chemicals or water to aid in extinguishing fires. Fire extinguishers can keep small fires from spreading, assist in fighting fires until the Fire Department arrives, and may help provide an escape route for you. A fire extinguisher is no substitute for the Fire Department. The Standing rule is to Always call the Fire Department first no matter how small you think the fire is.

A comprehensive fire extinguisher safety program includes both educational components and hands-on instructional opportunities to ensure students and employees understand the relevant information and have the ability to put that knowledge to use in practice.

The key elements in the program are:


- 1. **Fire source**: Describe the basic source of fire and various methods for halting combustion process. Understanding what type of fire extinguisher is most effective for a given hazard.
- 2. **Fire classes and Fire Extinguishers**: How different agents extinguish classes of fire and importance of selecting the proper fire extinguisher.
- 3. **Identifying a Fire Extinguisher**: Discuss the distinguishing features and characteristics of extinguishers.
- 4. **Practical Training**: Hands-on fire exercise will significantly increase familiarization with the operation of fire extinguisher.

12.1 The Fire Triangle

Four things must be present at the same time in order to produce fire

- 1. Enough oxygen to sustain combustion
- 2. Enough heat to raise the material to its ignition temperature
- 3. Some sort of fuel or combustible material, and
- 4. The chemical, exothermic chain reaction that is fire

Oxygen, heat and fuel are frequently referred to as the "fire triangle." Add the fourth element, the chemical chain reaction, and you actually have the "fire tetrahedron." The important thing



to remember is when you take any of these four things away, you will not have a fire, or the fire will be extinguished.

Essentially, fire extinguishers put out fires by taking away one or more elements of the fire triangle/tetrahedron. Fire safety, at its most basic, is based upon the principle of keeping fuel sources and ignition sources separate.

12.2 Classes of Fires

There are five classes of fires. All fire extinguishers are labeled using symbols for the classes of fires they can put out. A red slash through any of the symbols tells you the extinguisher cannot be used on that class of fire. A missing symbol tells you only that the extinguisher has not been tested for that class of fire.

- 1. Class A fires involve paper, wood, and other ordinary combustibles.
- 2. Class B fires involve flammable liquids, such as gasoline, oil, and some paints and solvents.
- 3. **Class C** fires involve energized electrical equipment such as power tools, wiring, fuse boxes, appliances, TVs, computers, electric motors, etc.
- 4. Class D fires involve combustible metals, such as magnesium, potassium, and sodium.
- 5. **Class K** fires involve grease in commercial cooking equipment.

12.3 Types of Fire Extinguishers

Different types of fire extinguishers are designed to fight different classes of fire. The extinguisher must be appropriate for the type of fire being fought.






Pressurized water extinguishers are being phased out because they do not work with class B and C fires. They can be used for ordinary combustibles like wood, paper, many plastics, cloth and rubber.



Carbon dioxide
extinguishers are generally
used in areas of sensitive
electrical or electronic
equipment since it is gas and
leaves no residue that
damages the equipment.
Carbon dioxide functions by

removing or displacing the oxygen in a fire. It is a non-flammable gas, extremely cold.



Dry chemical fire extinguishers are by far the most common on campus. ABC or multipurpose fire extinguishers are effective on all three classes of fires. Dry chemicals function by interrupting the chain reaction of the fire tetrahedron. The extinguishers are pressurized with nitrogen gas as an expellant. They can be used on class A, B and C fires. Dry chemical extinguishers put out fires by coating the fuel with thin layer of chemical dust. This in turn separates the fuel from the oxygen in the air. The powder has also the ability to interrupt the chemical chain reaction of the fire. These are the most common extinguishers found on campus since they are very effective at extinguishing fires.



K-Class Extinguishers contains a wet chemical that is composed of potassium-based solution. They are used on kitchen fires that involve high temperature cooking oils and deep fat fryers. The solution provides both a cooling effect on the fire as well as forming a blanket on top of the fire cutting off the oxygen.

12.4 How to Use a Fire Extinguisher

It is easy to remember how to use a fire extinguisher if you can remember the acronym **PASS**, which stands for **PULL**, **AIM**, **SQUEEZE**, and **SWEEP**.



Pull the pin.

This will allow you to discharge the fire extinguisher.



Aim at the base of the fire.

If you aim at the flames (which is usually the temptation), the extinguisher agent will fly right through and do no good. You have to hit the fuel



Squeeze the top handle or lever.

This depresses a button that releases the pressurized extinguishing agent in the extinguisher.



Sweep from side to side until the fire is completely out.

Start using the extinguisher from a safe distance away moving forward while sweeping the nozzle from side to side. Once the fire is out, keep an eye on the area in case it re-ignites.

12.5 Rules for Fighting Fires

Fires can be very dangerous and you should always make certain to not endanger yourself or others when attempting to put out a fire. For this reason, when a fire is discovered:

- Assist any person, who is in any immediate danger to safety, if it can be accomplished without risk to you.
- Activate the building fire alarm system or notify the fire department by dialing 911. When
 you activate the building fire alarm system, it will automatically notify the fire department
 and get help on the way. It will also sound the building fire alarm system to notify other
 occupants, and it will shut down the air-handling units to prevent the spread of smoke
 throughout the building.
- Only after completing the above two, you may use an extinguisher if you are trained and the fire is small.

However, before deciding to fight the fire, keep these rules in mind:

NEVER FIGHT A FIRE IF:

• You do not know what is burning and you do not know what type of fire extinguisher to use. Even if you have an ABC extinguisher, there may be something in the fire, which could explode or produce toxic smoke. Chances are you know what is burning, or at least have a pretty good idea, but if you do not know, let the fire department handle it.

• The fire is spreading rapidly beyond the spot where it is started. The time to use the fire extinguisher is in the recipient, or beginning stages of the fire. If the fire is spreading quickly, it is best to simply evacuate the building, closing windows and doors as you leave.

12.6 Mounting Fire Extinguishers

Most fire extinguishers are mounted on walls or columns by securely fastened hangers so that they are supported adequately, although some fire extinguishers are mounted in cabinets or wall recesses. In any case, the operating instructions must face outward, and the extinguisher should be placed so that it can be removed easily. Cabinets should be kept clean and dry.

12.7 Tampering/Vandalism

Tampering with, or vandalizing, a fire extinguisher includes the following:

- Discharging the extinguisher for any other reason than to extinguish a fire.
- Relocating an extinguisher without approval.
- Damaging any part of the extinguisher intentionally or accidentally through carelessness.

12.8 Reporting Damaged or Discharged Extinguisher

Never put an extinguisher back in its place after use. If an extinguisher is discharged, or if it is damaged in any way, report the fire extinguisher to EH&S.

12.9 Maintenance

Maintenance should include a thorough examination of the extinguisher's mechanical parts, the extinguishing agent and the expelling means.

The purpose of the maintenance program is to make sure that the extinguisher will operate properly, and will not pose a potential hazard to the operator or people nearby. Certified personnel will perform maintenance once every year as per NFPA 10.

12.10 Guidelines for Inspection and Maintenance of Fire Extinguishers

All fire extinguishers in FAU buildings/facilities will be inspected and maintained in accordance with the manufacturers established operating standards and NFPA 10. NFPA 10 requires extinguishers be inspected when they are initially installed and monthly afterwards in addition to annual servicing. Annual servicing, recharging, or testing of fire extinguishers shall only performed by licensed and certified companies with qualified personnel normally engaged in this type of work.

The monthly inspection shall include check of the following items.

- 1. The extinguisher is located in its designated location.
- 2. There is no obstruction to access or visibility.
- 3. Operating instructions on the name plate are legible and facing outward.
- 4. Seals and tamper indicators are in place and not broken or missing.
- 5. The extinguisher is full determined by weighing or "hefting".
- 6. Extinguisher shows no obvious physical damage, corrosion, leakage, or clogged nozzle.
- 7. Pressure gauge reading or indicator is in the operable range or position.

- 8. Extinguisher chemical is not caked. (dry chemical only).
- 9. Tag is attached that indicates the month and year the maintenance and recharging were performed and identifies the person performing the service.

Annual maintenance will include the above inspection items as well as the following:

- 1. Thorough examination of the basic elements of a fire extinguisher annually including:
 - a. All necessary parts of fire extinguishers
 - b. Extinguishing agent of both cartridge and cylinder-operated dry chemical, stored pressure, loaded steam and pump tank fire extinguishers
 - c. Expelling means of all extinguishers
 - d. Weigh all carbon dioxide and halogenated fire extinguishers as required by the manufacturer.
- 2. As part of the annual maintenance and where applicable conductivity test shall be performed on carbon dioxide fire extinguishers hoses.
- 3. When recharging a fire extinguisher, the recommendations of the manufacturer shall be followed and a leak test shall be performed on stored pressure and self-expelling types of fire extinguishers.
- 4. All fire extinguishers that require recharging as a result of either six-year maintenance or hydrostatic testing must have "Verification of Service" collar located around the neck of the container.
- 5. Dry chemical and Halon fire extinguishers shall be serviced every six years. Six –year maintenance involves taking apart the fire extinguisher to internally examine all components.
- 6. Every six years stored pressure fire extinguishers that require a 12-year hydrostatic test shall be emptied and subjected to the applicable maintenance procedures.
- 7. Every 12-year, extinguishers must be hydrostatically tested. Test involves high pressure testing to determine continued serviceability to the extinguisher shell.
- 8. As part of hydro testing of carbon dioxide fire extinguishers conductivity test shall be performed on all on all carbon dioxide fire extinguishers hoses that require such testing. Hose assemblies found to be nonconductive shall be replaced. Carbon dioxide fire extinguishers are not required to be examined internally. However, these extinguishers must be weighed on a special scale to determine if the amount of carbon dioxide is within the required range. Carbon dioxide fire extinguishers are subject to hydrostatic test testing every five years.
- 9. Each fire extinguisher shall have a tag or label securely attached that indicates the month and the year the maintenance was performed. The tag must identify the technician name, license number and the company name.
- 10. During the maintenance and inspection of fire extinguishers, any extinguisher that is identified, as having a deficiency the inspecting company shall immediately replace the fire extinguisher with the same type and size by a loaner.
- 11. All inspection, testing and maintenance shall be performed in compliance with applicable NFPA standards and documented accordingly.

13 INSPECTION AND TESTING OF FIRE PROTECTION AND LIFE SAFETY SYSTEMS

FAU strives to provide a level of life safety and property protection that will meet the needs of the people occupying its buildings while meeting the safety requirements of local building codes and the authority having jurisdiction. Fire detection devices and alarm systems are the key elements among the fire protective features of any facility. Detection and alarm systems help limit property losses in buildings regardless of the type of occupancy, and significantly reduce the loss of life from fire since many of the fire deaths in the United States result from building fires.

13.1 Fire Protection Equipment and Systems

Fire Protection Equipment and systems are specially designed, either alone or as a system, to limit the spread of fire and smoke by assisting in extinguishments, either by automatic, semiautomatic or manual means. This includes, but is not limited to:

- · Portable fire extinguishers
- Fire hoses
- Fire pumps
- Wet and dry standpipe systems
- Automatic sprinkler systems
- Halon systems and other special extinguishing systems
- Fire doors, dampers and other fire protection systems and appurtenances
- Fire alarm systems

Fire protection and life-safety equipment and systems shall be inspected, tested and maintained in all occupancies and locations where required, or installed as set forth in NFPA Codes, federal, state, and local standards, and as may be required by the State Fire Marshal.

The provisions of this Standard apply to the inspection, maintenance, and testing of both fire protection and life-safety systems and equipment. The requirements presented in this Standard are to be considered as a MINIMUM.

13.2 Servicing, Testing, and Maintenance

Qualified, certified and/or licensed personnel shall conduct all servicing, testing, repair, maintenance and tagging of fire protection and life-safety equipment. Personnel not licensed, certified, or approved by State of Florida may be required to provide documentation of licensing or certification by similar approved agencies or authorities, or identification as manufacturer's representative or authorized service personnel.

13.3 Service Tags

After installation or service, an approval service tag shall be completed in detail indicating all work that has been done and then attached to the equipment or system in such a position as to permit convenient inspection and not hamper its actuation or operation. A new service tag must be attached each time service is performed. If impairments to the system constitute emergency impairments as defined in applicable NFPA Standards, then a completed tag shall be attached indicating the nature of the impairment or what corrective action is necessary.

13.4 New Installation

All new installations of fire protection equipment and fire alarm systems shall have installation acceptance tags affixed to them.

13.5 Upgrade of Equipment

All fire protection and life-safety equipment shall be maintained in accordance with requirements of the manufacturer and local, state, federal or nationally recognized standards in effect at the time of original installation and acceptance, unless otherwise required by the State Fire Marshall or other regulatory agencies.

13.6 Inspection and Maintenance Records

All logs or records of inspection, testing, maintenance and major repairs of fire protection and life-safety equipment and systems shall be maintained on file for not less than **3 years**, and made available to the State Fire Marshal or AHJ upon request.

13.7 Notification of Systems Out of Service

The Fire Department should be notified immediately when a required fire protection or life safety system is placed out of service for emergency or non-scheduled repairs, replacement, or service. The Fire Department shall again be notified when the system is restored to normal operational status.

The office of the State Fire Marshal shall be notified, **in writing**, not less than **7 days** prior to any lengthy routine or scheduled repairs, or replacement time period. Notification shall be prior to, where possible, placing the system out of service. Certification and documentation of repairs and operational readiness of the system shall be provided to the State Fire Marshal or fire inspector upon request.

No fire protection or life-safety system shall be placed permanently out of service unless prior written approval is obtained from the State Fire Marshal.

13.8 Life Safety Systems

13.8.1 Fire Alarm Systems

Fire alarm systems shall be tested, and service tagged at the main alarm panel, not less than **annually**. Testing shall include all smoke detectors, manual pull devices, annunciators, visual indicators and strobes, control units, voice/alarm communications systems and other devices that may be part of the fire alarm system.

13.8.2 Test of Systems

An approved fire alarm service company shall test the fire alarm system. All testing and maintenance shall be in accordance with NFPA Standard No. 72.

13.8.3 Emergency Lighting Systems

Provide for the monthly testing of emergency lighting systems that are part of an approved exit system and shall include, but is not limited to: lighted exit signs, stairway lighting, and egress lighting, where required both inside and outside of a building or structure.

13.8.4 Generator Systems

A "run check" of the generator unit shall be performed at least **monthly**, for a period of at least **30 minutes**, under load conditions. System shall be checked for proper fuel, oil and coolant levels prior to starting test. Authorized building or contract personnel may perform "Run Tests" and maintenance. All testing should be done in accordance with manufacturer's guidelines and NFPA 110. A written record of monthly test shall be maintained by FAU Facilities.

13.8.5 Battery Systems

Battery units shall be inspected **quarterly**. Authorized building or contract personnel may perform inspections using procedures in accordance with manufacturer's guidelines and NFPA 110. A written record of inspections shall be maintained.

13.8.6 Emergency Power Supply Systems (EPSS)

These systems provide emergency power for continuous operation of, but are not limited to: exit lighting systems, fire alarm system, fire pump, stair pressurization and smoke removal systems, elevators, and associated electrical transfer switch gear. The unit shall be inspected quarterly.

13.8.7 Engine Driven Generator Systems

An authorized generator company shall conduct an annual 'Load Test'. Load test shall be performed under temperature conditions and at a capacity not less than **50 percent** of the total connected emergency power supply load manufacturer's nameplate rating for the unit, for a continuous period of not less than **90 minutes**. Load test shall include building load with all required equipment on the emergency circuit(s) operational for the duration of the test. Elevator recall and firefighter control operations shall be checked, but need not be continuous for the test period.

13.9 Water based Life Safety Systems

13.9.1 Automatic Sprinkler Systems

13.9.1.1 Routine Inspection

Approved contract personnel or building personnel, fully trained to perform such inspections or checks, may perform routine visual inspections and equipment checks in accordance with NFPA 25. A written record of inspections of system components shall be maintained.

Regardless of the type of system, all automatic fire sprinklers must remain clean at all times. They must not be caked with dust, grease, or paint, particularly on the heat responsive element. They must be provided with guards if located in the areas prone to damage. Light fixtures, HVAC equipment, cables, stored materials, or movement of overhead doors and windows should not obstruct sprinklers. NFPA 25 requires this type of evaluation to be performed once a year. Sprinklers must be free from corrosion. A sufficient supply of spare sprinkler heads of each type and ratings used by the system and the special wrench needed to replace them, must be available on the premises.

Piping must be checked once a year when the sprinklers are being inspected to make sure it is in good condition, free from mechanical damage, and not being used to support fixtures, ladders, or any other loads.

13.9.1.2 Test of Systems

All automatic sprinkler systems shall be tested **annually** in accordance with NFPA 25 and service tagged by an approved fire protection sprinkler company.

13.9.1.3 Wet Standpipe System

Wet standpipe systems should contain water in the piping at all times. A flow test shall be conducted for each zone of the standpipe system every **5 years**. An approved service company shall conduct flow tests with required volume of water at the system's design pressure and provide required service tagging of the system at the main control valves and risers. Testing shall be conducted in accordance with NFPA 25.

13.9.1.4 Dry Standpipe System

Dry standpipe systems do not normally contain water in the piping and have to be supplied with water from an outside source. An approved service company performing such testing shall conduct hydrostatic test on the standpipe system every **5 years**.

13.9.2 Fire Department Connections

13.9.2.1 Inspection

Fire Department Connections (FDC) shall be inspected **quarterly**. Inspections should check for: missing protective caps or covers, damaged hose couplings, couplings not operating freely, the presence of foreign material that might interfere with operation of system, water in the piping that could indicate possible check valve leaks, and missing standpipe or sprinkler connection identification signs.

13.9.2.2 Test of System

An approved service company shall conduct flow and pressure tests of all fire department connections, piping and check valve assemblies, not less than every **5 years**. Testing should be conducted as a part of the standpipe system 5-year test when possible, and in accordance with NFPA 25.

13.9.3 Fire Pumps

13.9.3.1 Pump Tests

A flow test at pressure shall be conducted on fire pump(s) **annually**. Flow tests shall be performed by an approved service company, and shall be conducted and service tagged in accordance with manufacturer's guidelines and NFPA Standard No. 25.

13.9.2 Private Fire Service Mains

Private dry barrel and wet barrel fire hydrants, and wall hydrants, installed for fire department use shall be inspected and flow tested by an approved service company **annually**. Testing shall be conducted in accordance with NFPA 25, and a written report of the test findings shall be provided to EH&S.

13.10 Fire Doors and Dampers

13.10.1 Fire Door Inspection

Fire doors, shutters and windows should be inspected at least **Annually**. Inspections should include the following:

- 1. Guides and bearing should be well lubricated.
- 2. Doors normally held open by automatic closing devices should be operated to assure they are working properly. Closing devices and coordinators should be adjusted to assure that the doors close and latch properly.
- Chains and cables should be regularly inspected for excessive wear and stretching. Ropes or other non-approved chain or cable replacements shall not be installed or used on fire doors.
- 4. Check fusible links for paint or other non-approved coating materials. Replace any painted or coated links.
- 5. Check door rollers for paint, dirt or grime buildup. Remove paint or buildup as necessary to assure that rollers will not bind.
- 6. Check doors for holes or other damage that would violate their fire rating.

Inspections may be performed by authorized building or contract personnel and shall be in accordance with the manufacturer's guidelines and NFPA 80. A written record of all inspections shall be maintained.

13.10.2 Fire Door Testing

All sliding and rolling fire doors, shutters and windows shall be allowed to close completely at least **annually** to check operations of the guides and rollers, and to make sure the doors have adequate clearance to close completely. Chains and cables should be adjusted as needed. An approved service company shall perform any required repairs of fire doors or assemblies. A written record of all inspections and repairs shall be maintained.

13.10.3 Fire Damper Inspections

All accessible fire damper assemblies in mechanical, electrical or air handler rooms and spaces, in firewalls or rated occupancy separation walls, or in floors, shall be visually inspected at least **quarterly** to verify that their operations are not obstructed or impaired. Authorized building or contract personnel may perform visual inspections. A written record of inspections shall be provided to EHS.

13.11 Special Fire Suppression Systems

13.11.1 Commercial Kitchen Hood Systems

All vent hood fire suppression systems installed in commercial kitchens shall be inspected and service tagged not less than **every 6 months**, and after any activation of the system by an approved fire protection equipment company. Inspections shall be in accordance with manufacturer's guidelines.

Additionally, all commercial kitchen vent hoods, exhaust ducts, exhaust fans and appurtenances shall be cleaned and inspected by approved personnel in accordance with manufacturer's guidelines as often as necessary to insure against excess grease accumulations.

13.11.2 "Type K" Extinguishing Systems and Portable Fire Extinguishers

"Type K" extinguishing systems and portable fire extinguishers, installed for use in the protection of cooking areas within commercial kitchens, shall be inspected, tested, service tagged and maintained in accordance with manufacturer's guidelines and NFPA 10.

13.11.3 Fixed Dry Chemical Extinguishing Systems

Fixed dry chemical extinguishing systems where installed for protection of, but not limited to, the following: dip tanks or process hazards as spray booths, chemical hood systems or laboratory hood systems; shall have an actuating test of the system performed (discharge of the agent is not required) and service tags affixed every **6 months** by an approved fire protection equipment company.

13.11.4 Fixed Wet Chemical Extinguishing Systems

Fixed wet chemical extinguishing systems where installed for protection of, but not limited to, the following: dip tanks or process hazards as spray booths, chemical hood systems or laboratory hood systems; shall have an actuating test of the system performed (discharge of the agent is not required) and service tags affixed every **6 months** by an approved fire protection equipment company. Inspections shall be in accordance with manufacturer's guidelines.

Appendix 1 – Fire Drill Response Form

Note: This form should be completed for any scheduled fire drill or any false alarm which results in a building evacuation. If you require help or have questions regarding this form, call EH&S at 7-3129.

<u>Sectio</u>	<u>n 1: Gen</u>	eral Infor	<u>mation</u>					
	Date/Tin	ne Fire Dri	II conducted:					
	Building	Name and	d No:					
	Person S	Supervisin	g the Fire Dri	II:				
Sectio	n 2: Alar	m Informa	ation_					
	Time Ala	arm Set-Of	ff:					
	Time Ala	arm Silenc	ed:					
	Alarm	Signal	Received	by \square		Dispatcher	Yes	No
	Reset	Signal	Received	by \square		Dispatcher	Yes	No
	Did Alar	m Devices	Activate?					
	Was the	re any trou	uble with the a	alarm panel,	or ini	tiating device	s?	
<u>Sectio</u>	n 3: Eva	cuation In	<u>formation</u>					
	Did ever	yone in the	e building eva	acuate?	⁄es	□No		
	Evacuat	ion time:						
	Was the	evacuatio	n orderly?	☐Yes ☐N	lo			
	Did ever	yone proc	eed to the pre	edetermined	asse	mbly area?		
	Any comments or recommendation on the evacuation:							

Appendix 2 - FAU Event Planning Checklist

This document has been developed as a management tool for University sponsored campus events. Through the use of this checklist accepted safety, environmental health and risk management standards and techniques can be applied to help insure a successful and accident-free event.

Any "No" answer requires contacting Environmental Health & Safety.

A.	SITE SELECTION Yes No N/A					
1.	Has the occupancy load/limit been determined for location to be used?					
2.	Are stages and platforms appropriately guarded and edges and steps highlighted for clear visibility? (Please note all stages, platforms, and tents require a FAU Building Permit and inspection prior to use.)					
3.	Is the location adequately illuminated for the time and type of event?					
4.	Have special lighting arrangements been made for outdoor locations, e.g. flashlights, spotlights, security lighting?					
5.	Does the location have at least two means of egress that are remote from each other?					
6.	Are all exits clearly visible and marked to identify them as such?					
7.	Are exits so arranged and maintained as to provide free and unobstructed egress from all occupied areas? (No exit may be blocked/obstructed in any way or locked from the inside; rugs, mats, electrical extension cords or other cables may not be placed across exit corridors so that they impede clear access to the exit doors and corridor.)					
8.	Have stairs/stairwells and handrails been inspected to assure that they are in good condition> (No storage is permitted in stairwells or under stairs at any time.)					
9.	Will tents be used? (Assembly and maintenance of tents must comply with requirements of NFPA standards 101 & 102 and obtain a FAU Tent Permit.)					
10	Have walkways leading to and from event site been inspected for potential slip & fall and trip & fall hazards? (Slip/trip/fall hazards must be corrected or occupant exposure of participants to these hazards must be prevented prior and during the event.)					
11	. Have grassy areas to be used or in close proximity been inspected for holes and other hazards?					

В. С	PERATIONS	Yes	No	N/A
1.	Does this event require coordination with the Physical Facilities Department? (Representative events that might require coordination include bonfires, facility setup, area clean-up, or special equipment requirements.)			
2.	Is the setup planned such that aisle ways and doorways are free of cords, protrusions and other obstructions that could cause tripping or struck-by injuries?			
3.	Have arrangements been made for emergency lighting? (Outdoor activities may meet this requirement using large battery-operated flashlights.)			
4.	Have responsibilities for execution of emergency evacuation procedures been addressed?			
5. 1	Have appropriate accommodation been made for emergency evacuation for persons with disabilities?			
6.	Is the event setup planned such that access to alarm activation and warning devices are kept clear and accessible?			
7.	Have security arrangements been confirmed with FAU Police Department?			
8.	In addition to 7 above, have procedures been established for effective crowd control?			
9.	Have arrangements been made to setup barricades to clearly delineate area for pedestrian and vehicular traffic?			
10.	When required, have arrangements been made to maintain radio communication between event organizers and event staff?			
11.	Will event staff be clearly identifiable so that guests may request help or information?			
12.	Have responsible individuals been identified to conduct roving inspections during event? (Aware of general and specific crowd control, suspicious activity, hazards, etc.)			
13.	Are procedures in place to enforce the state statute which prohibits smoking in public buildings?			
14.	Will any Special Equipment, High Risk Activity, or Animals be involved in the event?			
15.	Have ADA accommodations been made to assist persons with disabilities to fully participate in the event as planned? (Mobility Impairments, Sight Impairments, Speech Impairments, Hearing Impairments, Others)			

C.	EVENTS INVOLVING FIRE, FLAME AND/OR HEAT	Yes	No	N/A
1.	Have all combustible decorative materials that will be used in building been treated with flame retardant?			
2.	If a firework display is desired to occur, has a request for the use of pyrotechnic devices been submitted to EH&S for this event? (See Section 8.1.6.11 Fireworks, Pyrotechnics, and Flame Effects for guidance.)			
3.	If a bonfire is desired to be at the event, has a request for a Bonfire been submitted to EH&S for this event? (See Section 8.1.6.10 Bonfires and Other Outdoor Fires for guidance.)			
4.	If you plan to have a barbeque at the event, has EH&S been notified?			
5.	Is the use of all "open flames" inside the building prohibited for this event? (Burning candles and all other forms of open flames are prohibited inside buildings)			
6.	Has a request for the use of pyrotechnic devices been submitted to EH&S for this event? (See Section 8.1.6.11 Fireworks, Pyrotechnics, and Flame Effects for guidance.)			
7.	Are barbeque grills setup at least 20 ft. from any building?			
8.	Is a portable fire extinguisher available within 25 feet barbeque grills?			



ENVIRONMENTAL HEALTH AND SAFETY 777 GLADES ROAD, BLDG 69, ROOM 112 BOCA RATON, FLORIDA 33431-0991 (561) 297-3129, FAX (561) 297-2210

Email: ehs@fau.edu Web Page: www.fau.edu/ehs

Appendix 3: Request For Use of Pyrotechnics Before a Proximate Audience

Name of person, group or organization sponsoring the production	n
Date(s) and Time(s) of the production	Exact location of the production
Number and types of pyrotechnic devices and material to be use	ed
Person in charge of firing the pyrotechnics	Pyrotechnics License ID (if applicable)
Qualifications / Experience of the pyrotechnics operator(s)	
Applicable State and Federal license(s) held by operator	
Number and types of pyrotechnics devices to be used	
Manner & place of storage for the pyrotechnic materials & device	e
Certification	
My signature below certifies that the set, scenery, and rigging mabeen treated to achieve flame retardancy, and that all material was of the pyrotechnic effects shall be inherently flame retardant retardancy.	orn by performers in the fallout area during
Signature of Sponsor	Date
Dean/Division Head Approval: Y/NSignature of Dean/I	Division Head
Attach a diagram to this request of the facility where the producti- point at which the pyrotechnic devices are fired, the fallout radius performance, and the lines behind which the audience shall be re-	s for each pyrotechnic device used in the

Attach a copy of the MSDS (Material Safety Data Sheet) for the pyrotechnic(s) to be used to this request.



ENVIRONMENTAL HEALTH AND SAFETY 777 GLADES ROAD, BLDG 69, ROOM 112 BOCA RATON, FLORIDA 33431-0991 (561) 297-3129, FAX (561) 297-2210

Email: ehs@fau.edu Web Page: www.fau.edu/ehs

Appendix 4 - Request For Use of Flame Effects Before an Audience

Name of person, group or organization sponsoring the produ	uction
Date(s) and Time(s) of the production	Location of the production
Flame Effects Classification	
Fuels used in the effect and their estimated consumption	
Air source for combustion and ventilation of effects	
Supplemental fire protection features	
Person in charge of effects	

Additional Information

A site plan shall be submitted with this request containing the following information:

- 1) A narrative description of the flame effect.
- 2) The location of flame effect devices to be fired and their control and sequence.
- 3) The area affected by the flame effect device.
- 4) Location of the audience.
- 5) Storage and holding areas.
- 6) Emergency response procedures.
- 7) Means of egress (exiting)

Attach a copy of the MSDS (Material Safety Data Sheet) for the materials (fuels) consumed in the flame effect.